

UIIU-ENG 84-3603

Report No. 103

SPECTROSCOPIC MEASUREMENT OF HYDROGEN
CONTAMINATION IN WELD ARC PLASMAS

by

J. E. Shea* and C. S. Gardner

Radio Research Laboratory
Department of Electrical Engineering, UIUC

*Presently with National Security Company, Baltimore, MD

A Report of the

MATERIALS ENGINEERING - MECHANICAL BEHAVIOR

College of Engineering, University of Illinois at Urbana-Champaign

February 1984

ABSTRACT

The introduction of hydrogen into metals during welding is known to cause hydrogen assisted cracking and embrittlement in certain situations. It has been shown that the weld metal hydrogen content is directly related to hydrogen concentration in the weld arc plasma. In this paper we describe a simple spectroscopic technique for measuring the arc plasma hydrogen concentration in real time when an argon shield gas is used. This technique is based on the fact that the intensity ratio of the hydrogen Balmer Alpha emission line at 6563\AA and an argon emission line at 6965\AA was observed to an approximately linear function of hydrogen concentration in the weld arc plasma. This technique was experimentally verified under a variety of welding conditions for gas metal arc welding and found to have an error of less than 10% when measuring hydrogen concentrations in the arc plasma as low as 0.25% by volume. This method of hydrogen measurement is also applicable when welding with shield gases not containing argon so long as a suitable ratioing line is available.

PACS numbers: 52.70.Kz, 07.65.EH, 52.80.Mg, 81.40Np

ACKNOWLEDGEMENTS

The authors would like to acknowledge F. Kearney, D. Blackmon, F. Kisters and V. Hock of the U.S. Army Construction Engineering Research Laboratory for developing the gas mixing system and for their help in collecting the arc spectral data. This work was supported by the U.S. Army Corps of Engineers under contracts DACA88-81-C-0003, DACA88-81-C-0016 and DACA88-82-M-0269.

TABLE OF CONTENTS

	Page
I. INTRODUCTION	1
II. THEORETICAL BACKGROUND	3
III. INSTRUMENTATION.	10
IV. EXPERIMENTAL RESULTS	19
A. Procedure.	19
B. Sample Spectra	19
C. Signal Processing.	21
D. Results.	28
E. Interference Filter Based H Monitor.	35
V. CONCLUSIONS.	39
APPENDIX A: SIGNAL PROCESSING SOFTWARE.	41
A.1. Main Program	42
A.2. Correlation Routine.	47
A.3. Integration Function	48
A.4. Filter Function.	49
A.5. Disk Read Routine.	50
APPENDIX B: STATISTICAL ANALYSIS OF SPECTRAL DATA	52
B.1. Variation of Hydrogen Concentration of Shield Gas.	53
B.1.1. Data Set No. 1	53
B.1.2. Data Set No. 2	61
B.1.3. Data Set No. 3	69
B.2. Variation of Travel Speed.	77
B.2.1. 1 Percent Hydrogen	77
B.2.2. 0.5 Percent Hydrogen	81
B.3. Filter Simulation on Date Set No. 1	85
B.3.1. 10 Å Filter.	85
B.3.2. 20 Å Filter.	92
B.3.3. 50 Å Filter.	99
B.3.4. 100 Å Filter	106
REFERENCES.	113



LIST OF TABLES

Table		Page
1.	SYSTEM SPECIFICATIONS.	16
2.	ERROR IN SETTING HYDROGEN CONTENT OF SHIELD GAS.	18
3.	E70S-3 WELDING WIRE COMPOSITION (%) ASTM 242 LOW ALLOY STEEL COMPOSITION (%)	20
4.	CORRELATION COEFFICIENTS	26
5.	LINEAR REGRESSION.	30

LIST OF FIGURES

Figure	Page
1. Block diagram of hydrogen monitor.	11
2. Optical fiber transmittance curve.	12
3. Photodiode array optical response.	14
4. 6475 Å - 6975 Å spectral sample. Two percent hydrogen added to shield gas	22
5. Expanded hydrogen spectra.	23
6. Hydrogen line intensity versus hydrogen concentration.	25
7. Intensity ratio versus hydrogen concentration.	29
8. 6475 Å - 6975 Å spectral sample. No hydrogen added to shield gas.	31
9. Ratio error versus hydrogen concentration.	33
10. Intensity ratio variation versus travel speed.	34
11. Intensity ratio versus hydrogen concentration.	37
12. Ratio error versus filter bandwidth.	38

I. INTRODUCTION

Hydrogen assisted cracking and embrittlement are often responsible for weld failure in high strength steels. During welding, hydrogen may be introduced into the weldment because molten metal will absorb hydrogen in proportion to its concentration in the arc atmosphere [1]. The most common sources of hydrogen in the weld arc plasma are the disassociation of hydrogen bearing compounds such as water vapor, lubricants, and electrode coatings. Once hydrogen has been introduced into the metal, cracking may occur as a result of interactions between the dissolved hydrogen and the metal [2], [3]. Savage, Nippes, and Husa [1] have analyzed the transfer of hydrogen from the weld arc plasma to the weldment when an AX-140 electrode is deposited on HY-130 plate. In their experiments, hydrogen was introduced into the arc plasma by either adding water vapor or hydrogen gas to the shield gas. They concluded that hydrogen induced cracking occurs when the volume of dissolved hydrogen exceeds 1 ppm in the weldment. This corresponds to a hydrogen concentration of approximately 0.25% of the shield gas.

To minimize hydrogen assisted cracking and embrittlement in critical welds, low moisture electrodes and special welding procedures have been developed. However, in practice, it is not always possible to guarantee strict adherence to the proper welding procedures. Consequently, in many cases, the welds must be carefully inspected to insure their integrity. The cost of locating and repairing defective welds is high. For the past few years, we have been developing a real-time weld quality monitor to detect defects as they occur [4]. In this paper, we discuss the development of an electro-optic based system to monitor in real time the concentration of hydrogen in the weld arc plasma.

This system is based on the fact that the intensity of light emitted by the arc plasma at wavelengths corresponding to the atomic transitions of hydrogen is proportional to the hydrogen concentration in the plasma. By monitoring the hydrogen emission wavelengths in arc welding, it is possible to measure hydrogen in concentrations as low as 0.25% of the shield gas with an error of less than 10%. Similar accuracies have also been obtained in limited experiments with tungsten inert gas welding and laser welding.

II. THEORETICAL BACKGROUND

The optical emissions of the weld arc result from atoms radiating energy after having been excited by electron collisions. The wavelength of light emitted by a particular atom will depend on the excitation gained by the atom in its collision with an electron and the transition probability of a particular wavelength. If none of the optical energy is absorbed by the weld plasma, the intensity of a given spectral line will be proportional to the number of atoms radiating at that wavelength. This suggests that, if we measure the intensity of the spectral lines emitted by a particular element or compound, it should be possible to infer its concentration.

If we consider the weld plasma to be in local thermodynamic equilibrium, the excitation levels within the plasma take on a Boltzmann distribution. Thus, if N atoms of a particular element exist in the plasma, the number of atoms N_m which have an energy E_m is [5]

$$N_m = \frac{N g_m e^{-E_m/kT}}{B(T)} \quad (1)$$

where

$$T = \text{°K}$$

$$g_m = \text{degeneracy factor}$$

$$k = \text{Boltzmann's constant}$$

and $B(T)$ is the partition function

$$B(T) = \sum_{r=\text{all states}} g_r e^{-E_r/kT} \quad (2)$$

The optical energy, corresponding to an atomic transition from state m to n , emitted by the plasma from a small volume element Δv , is equal to $N_m A_{mn} \Delta v$ where A_{mn} is the transition probability from state m to n . Recalling that the

energy of a photon is $h\nu = E_m - E_n$, the intensity of the m-to-n transition per unit solid angle may be expressed as

$$I_{mn} = \frac{h\nu \Delta v N g_m A_{mn} e^{-E_m/kT}}{4\pi B(T)} \quad (3)$$

The total intensity of light emitted at a given wavelength may be found by integrating Eq. (3) over all volume elements (Δv) of the plasma. Unfortunately, random variations in factors such as temperature and volume of excited gas severely limit the accuracy of this method. Changes in temperature may be caused by variations in the arc length and current. Furthermore, the temperature inside of the arc is not uniform, but decreases radially from the center of the plasma. The volume of excited gas will change with any instability in the arc, which has the effect of changing the parameter N in the intensity equation.

Not all of the light radiated from the plasma will reach the detector. A portion will be absorbed by smoke and particulate matter in the air. But more importantly, the amount of light actually received by the detector will critically depend on the alignment of the optical system used to collect the light. Any small pointing or focusing error will cause a significant change in the observed intensity.

Obviously, if the intensity measurements are to be of any value in determining concentrations, the variations due to random factors must somehow be removed by a normalization procedure. Probably the best way to normalize is to take a ratio of the spectral line intensities of two elements which have similar excitation energies, E_{m_i} . By choosing spectral lines with approximately equal excitation levels, temperature dependence is reduced. Furthermore, if the wavelengths of the two transitions are relatively close, scattering and other

wavelength dependent factors will affect each spectral line intensity in the same manner so that the ratio will be approximately constant for a given concentration of the two elements. The intensity ratio of spectral lines resulting from two different elements is

$$\frac{I_{m_1 n_1}}{I_{m_2 n_2}} = \frac{\nu_1}{\nu_2} \frac{N_1}{N_2} \frac{g_{m_1}}{g_{m_2}} \frac{A_{m_1 n_1}}{A_{m_2 n_2}} \frac{\exp(-E_{m_1}/kT)}{\exp(-E_{m_2}/kT)} \frac{B_1(T)}{B_2(T)} \quad (4)$$

If $E_{m_1} \approx E_{m_2}$

$$\frac{I_{m_1 n_1}}{I_{m_2 n_2}} \approx \frac{\nu_1}{\nu_2} \frac{N_1}{N_2} \frac{g_{m_1}}{g_{m_2}} \frac{A_{m_1 n_1}}{A_{m_2 n_2}} \frac{B_1(T)}{B_2(T)} \quad (5)$$

In general, the transition probabilities $A_{m_i n_i}$ are not well-known (typical errors for argon are $\pm 25\%$). But if the intensity ratios are found experimentally using plasmas of known compositions, it is possible to develop an empirical curve, relating observed intensity ratio to atomic concentration ratio $\frac{N_1}{N_2}$. This empirical curve may then be used to determine the concentration ratio of two elements from an observed intensity ratio.

Although, as we have just stated that $A_{m_1 n_1}$ and $A_{m_2 n_2}$ are generally not well-known, the ratio $A_{m_1 n_1}/A_{m_2 n_2}$ is well-known for the special case when both transitions are produced by the same element, and have the same lower state (i.e., $n = n_1 = n_2$). The intensity ratio may then be written as

$$\frac{I_{m_1 n}}{I_{m_2 n_2}} = \frac{\nu_1}{\nu_2} \frac{g_{m_1}}{g_{m_2}} \frac{A_{m_1 n}}{A_{m_2 n}} \frac{\exp(-E_{m_1}/kT)}{\exp(-E_{m_2}/kT)} \quad (6)$$

From this equation, it is evident that if the two transitions are chosen so that $E_{m_1} - E_{m_2}$ is large, the ratio may be solved for the plasma temperature

$$T = \frac{E_{m_1} - E_{m_2}}{k} \left[\ln \left(\frac{\nu_1}{\nu_2} \frac{g_{m_1}}{g_{m_2}} \frac{A_{m_1 n}}{A_{m_2 n}} \frac{I_{m_2 n}}{I_{m_1 n}} \right) \right]^{-1} \quad (7)$$

Thus far, we have considered the spectrum to be composed of discrete lines of negligible width, but in fact all spectral emissions have a non-zero width due to the finite lifetime of an atomic state. In a plasma, the lineshape will be even broader than that of the natural line width because processes such as Doppler broadening, pressure broadening and the Stark effect will increase the line width. If we again assume local thermodynamic equilibrium, the Doppler broadening may be calculated from [6]

$$\Delta\lambda = \left(\frac{8kT \ln 2}{mc^2} \right)^{1/2} \lambda_0 \quad (8)$$

m = atomic mass

c = speed of light .

In our welding work, the lines of primary interest are argon at 6965 Å, iron in the region of 6500 Å, and the hydrogen Balmer alpha line at 6563 Å. At 20,000 °K, these lines have the following Doppler line widths:

Argon: $\Delta\lambda_d = 0.110 \text{ Å}$
 Iron: $\Delta\lambda_d = 0.087 \text{ Å}$
 Hydrogen: $\Delta\lambda_d = 0.662 \text{ Å}$.

The calculation of pressure broadening is more complicated because we must know the collision frequency between the atoms in the plasma. To calculate the collision frequency, the collision cross section of the species in the plasma must be known, and, in general, can only be found experimentally. If we consider a plasma composed only of hydrogen and argon, the collision frequency can

be approximated using gas kinetic theory [7]. With argon as the background gas, the collision frequency of a hydrogen atom with argon is

$$v_{\text{col}} = \pi(r_A + r_B)^2 \left[\frac{8kT}{\pi} \left(\frac{1}{M_A} + \frac{1}{M_B} \right) \right]^{1/2} N_B \quad (9)$$

where

r_A, r_B = atomic radii

M_A, M_B = masses

N_B = number density of the background gas.

To find the collision frequency of argon, we use the rate at which an argon atom collides with the argon background gas.

$$v_{\text{col}} = \pi\sqrt{2} r_B^2 \left(\frac{8kT}{\pi M_B} \right)^{1/2} N_B \quad (10)$$

The pressure broadening is then found from [6]

$$\Delta\lambda = \frac{\lambda_o^2}{c} \left(\tau_n + \frac{v_{\text{col}}}{\pi} \right) \quad (11)$$

where τ_n is the natural lifetime. By substituting the collision frequencies in the above and assuming that the natural lifetime is small, we obtain

Argon: $\Delta\lambda = 0.003 \text{ \AA}$

Hydrogen: $\Delta\lambda = 0.006 \text{ \AA}$.

Obviously at welding temperatures and pressures, the effects of pressure broadening are insignificant when compared with the effects of Doppler broadening.

The final broadening mechanism to be considered, the Stark effect, may prove to be of particular importance in future work because the electron density of the plasma can be determined from the width of a Stark broadened hydrogen line. If we assume a quasistatic situation as set forth by Griem [8], the Stark broadening may be calculated as follows [9]:

$$\Delta\lambda = \frac{3\lambda_0^2 \epsilon_0 \hbar (n_1^2 - n_2^2) E}{m e c Z_e} \quad (12)$$

$$= C(\lambda_0) E \text{ \AA}$$

where

$$E \approx 3.4 E_0$$

and

$$E_0 = \frac{2.603 e N^{2/3}}{4 \pi \epsilon_0} \quad \text{is the Holtsmark normal field.}$$

ϵ_0 = dielectric constant of free space

$$\hbar = h/2\pi$$

h = Planck's constant

n_i = principal quantum number

m = electron mass

Z_e = particle charge

N = electron density

e = electron charge

c = speed of light

Bekefi [9] has tabulated values of $C(\lambda_0)$ for the prominent hydrogen lines. Typical electron densities for weld arc plasmas are on the order of 10^{16} cm^{-3} . By substituting this electron density into the above equation, we obtain

$\Delta\lambda \approx 10 \text{ \AA}$ for the hydrogen linewidth at 6563 \AA . At these electron densities, Stark broadening is only significant for hydrogen and helium.

In addition to spectral lines, optical spectra contain background emissions which are slowly varying functions of wavelength. These background emissions are the result of blackbody radiation. Since blackbody radiation is a function of temperature, the primary sources of blackbody radiation in a welding environment are the weld arc plasma and the base metal.

In the preceding discussion, we have assumed that all of the optical radiation generated by the plasma is emitted. Often times, this condition does not hold and some of the optical radiation emitted from the inside of the plasma is absorbed in a process known as radiation trapping [10]. Radiation trapping can have two effects on the observed spectrum. It may change the line shape of a spectral line, or it may redistribute the energy within the spectrum. Radiation trapping effects are most prevalent in so-called resonance transitions where an atomic transition occurs between an upper state and the ground state. Fortunately, most of the transitions which generate spectral lines of interest in arc welding are not resonance transitions. Therefore, radiation trapping is minimal, and can be neglected.

III. INSTRUMENTATION

Figure 1 is a block diagram of the hydrogen monitoring system. A lens, which is mounted on the weld head, focuses light from the weld arc onto a metal-clad, optical-fiber bundle. This fiber bundle guides the light to the entrance slit of a monochromator. In our application, the monochromator is operated as a spectrograph where the exit slit has been replaced by a linear photodiode array consisting of 1024 photodiodes. The photodiode array converts the spectrum to a series of analog voltages which are proportional to the light intensity. The spectrum along with the signals from the current, voltage, and travel speed transducers are digitized by an A/D converter, processed, and then stored on a floppy disk.

The lens used for focusing the light from the weld arc is a 25 mm convex lens with a focal length of 50 mm. Since the lens is mounted on the weld head, it always points at the arc as the welder traverses the work piece. Even though the lens is about two feet from the arc, metal splatter occasionally strikes it. Pitting is avoided by placing a disk of pyrex glass over the lens so that any metal splatter will strike the disk. When the glass disk is pitted to the extent that it affects light collection efficiency, it is replaced. The two-meter fiber optic cable that is used to guide the light from the lens to the monochromator is composed of glass fibers in a metal sheath. The metal protects the fibers from excessive bending, while at the same time adding mechanical strength. A graph of the transmittance of the fiber versus wavelength is shown in Figure 2. Because of absorption in the glass, ultraviolet (UV) radiation below 3500 Å is heavily attenuated.

A 0.32 meter Czerny-Turner type diffraction grating monochromator disperses the light from the weld arc into its spectral components. In this type of




Figure 1. Block diagram of hydrogen monitor.




Figure 2. Optical fiber transmittance curve.

monochromator, light is focused from the entrance slit onto the grating by a parabolic mirror. After the grating has dispersed the light, a second mirror focuses the spectrum onto the exit focal plane where a photodiode array is positioned. The angle of the diffraction grating with respect to the optical axis of the input mirror determines which portion of the spectrum is projected onto the photodiode array. This angle may be changed by rotating the grating, allowing the entire spectrum from the near infrared (IR) to the UV to be observed. Presently, a 1200 line/mm holographic grating is used for hydrogen detection, while a 2400 line/mm grating is used when higher resolution spectra are required. When the 1200 line/mm grating is used, a 500 Å band of the spectrum is focused onto the photodiode array. The monochromator optics and photodiode array impose a theoretical resolution limit of approximately 0.4 Å [11]. This resolution is comparable to the Doppler linewidths of argon and hydrogen.

The photodiode array consists of a linear array of 1024 photodiodes on a silicon bar one-inch long. The length of time that light is integrated by the array may be varied from 500 microseconds to several seconds. An integration time of 50 milliseconds was selected to minimize the effects of dark current. The voltages representing the optical energy integrated by the array are outputted in a serial staircase form suitable for A/D conversion. The spectral response of the photodiode array is illustrated in Figure 3. Notice the significant drop-off in the near IR region of the spectrum. The UV transmittance of the optical fiber and the near IR response of the photodiode array limit the overall spectral response of the system to the region from 3500 Å to 9000Å.

System control and data acquisition are implemented by a 16-bit LSI-11/23 microcomputer. The computer contains a parallel input output port and an analog-to-digital converter. The parallel I/O port is used to send commands




Figure 3. Photodiode array optical response.

to the interface electronics which enable the data acquisition. The analog-to-digital converter converts the analog staircase array voltages and the transducer outputs from the voltage, current and travel speed transducers to a signed 12-bit format. The minimum conversion time of the A/D converter is 10 microseconds or 100,000 voltage samples per second. With an array integration time of 50 milliseconds, the maximum data acquisition rate is 20 complete spectra per second. Each spectrum consists of 1024 samples uniformly distributed over a 500 Å band. If the spectra are stored on a floppy disk, the access time of the disk limits the data acquisition to approximately two spectra per second.

Table 1 gives a summary of the performance specifications of the data acquisition system. It should be noted that with the high resolution grating, the Doppler profile of the spectral lines is not quite resolvable. In choosing the 1200 line/mm grating and the 0.32 meter monochromator, a trade-off was made between the desire to observe as much of the spectrum as possible while at the same time preserving spectral resolution. In making this trade-off, we have designed the system resolution so that the atomic emission lines can be easily resolved, and so that significant effects such as Stark broadening are measurable. As shown in Table 1, the time resolution of the system is limited to 0.5 seconds when the data are stored on the disk. Even at this slow data acquisition rate, a considerable amount of data is generated on each welding run. If greater temporal resolution is desired, processing can be minimized by only recording the spectra near a few important wavelengths.

In this experiment, hydrogen was introduced into the weld arc plasma through the shield gas by mixing gas containing 98% argon and 2% oxygen with gas

TABLE 1

SYSTEM SPECIFICATIONS

Optical Resolution:	0.5 Å (1200 line/mm)	0.24 Å (2400 line/mm)
Bandwidth:	500 Å (1200 line/mm)	250 Å (2400 line/mm)
Time Resolution:	50 msec (0.5 sec when stored in disk)	
Current Transducer:	Hall Effect Transducer	
Voltage Transducer:	Voltage Divider	
Speed Transducer:	Tachometer	

containing 90% argon and 10% hydrogen. By regulating the flow rates of these two gases, the volume concentration of hydrogen in the shield gas can be varied from 0.00% to 3.00%. Table 2 lists the error in setting the hydrogen content of the shield gas which occur when reading the hydrogen flow rate meter.

TABLE 2

ERROR IN SETTING HYDROGEN CONTENT OF SHIELD GAS

%H	ERROR
0.00	$\pm 0.0\%$
0.25	$\pm 17.0\%$
0.50	$\pm 10.0\%$
0.75	$\pm 6.7\%$
1.00	$\pm 5.0\%$
1.25	$\pm 3.8\%$
1.50	$\pm 3.1\%$
1.75	$\pm 2.6\%$
2.00	$\pm 2.2\%$
2.25	$\pm 2.0\%$
2.50	$\pm 1.8\%$
2.75	$\pm 1.6\%$
3.00	$\pm 1.4\%$

IV. EXPERIMENTAL RESULTS

A. Procedure

The materials used for welding were ASTM-242 low-alloy, high-strength steel, and E70S-3 electrode wire. The nominal composition of these materials can be found in Table 3. In an effort to remove surface contaminants from the base metal, a small amount of the welding plate was ground away before welding.

All welding was performed on a semi-automatic Gas Metal Arc welder. This welder consisted of a welding head mounted to a carriage which was motorized on one axis. Generally, an arc length of 20 mm was used except when welding at hydrogen concentrations above 1.5%. At these higher concentrations, it was necessary to lengthen the arc to establish stable operation. The nominal values for welder voltage and current were 30 V and 300 A, respectively. Travel speed was varied from 10 cm/min (4 ipm) to 60 cm/min (24 ipm).

The first step when recording data was to adjust the welder for the proper current, voltage, and travel speed. The gas mixture was then adjusted for the desired hydrogen concentration, and the gas lines bled to remove any residual gases. After all preparations were completed, the welder was started. A single pass of the metal plate lasted approximately 25 seconds during which fifty spectra were acquired and stored on the floppy disk. In all of the welding performed in this experiment, a bead of metal was deposited on the base metal plate.

B. Sample Spectra

There are two prominent hydrogen lines in the visible region of the spectrum which can be used for monitoring hydrogen concentration. One is the Balmer series alpha line at 6563 Å, and the other is the Balmer series Beta line at 4861 Å. The 4861 Å line was not used because several emission lines of the

TABLE 3

E70S-3 WELDING WIRE COMPOSITON (%)

C	0.06-0.15
Mn	0.9-1.4
Si	0.45-0.70
P _{max}	0.025
S _{max}	0.035

ASTM 242 LOW ALLOY STEEL COMPOSITION (%)

C	0.12%
Mn	0.25
P	0.07-0.15
S	0.05 max
Si	0.25-0.55
Cu	0.25-0.40
Cr	0.4%-0.65
Va	0.02%-0.10%
Fe	Remainder

base metal interfered with the hydrogen spectrum. In addition, the 6563 Å line is near several strong argon emission lines which can be used for normalization.

Figure 4 is a spectral sample taken with the monochromator set at a center wavelength of 6725 Å and a hydrogen shield gas concentration of 2.0% by volume. Notice that most of the spectral lines are due to either hydrogen, argon, or iron. The hydrogen line is by far the broadest line in the spectrum. An expanded plot of the hydrogen line is shown in Figure 5. The large width of the hydrogen line relative to the other emission lines is due to the Stark broadening mechanism mentioned earlier.

C. Signal Processing

Both line broadening mechanisms and variations in the spectral background level will affect the peak intensity of a spectral line. When a line is broadened, the optical energy generated in an atomic transition is spread over a larger bandwidth. The effects of line broadening may be significantly reduced if the intensity is integrated over a substantial portion of the linewidth. Since an integral provides a measure of total energy, it should remain relatively constant regardless of linewidth.

The background level of the spectrum is due to two sources. The first source is the bias level of the photodiode array. The bias level may be set by adjusting a potentiometer in the interface electronics, but in time it will change due to drift in the electronic circuitry. The second source is blackbody emissions from the weld arc plasma and hot base metal. Because only a small portion of the spectrum is examined at any one time (i.e., 500 Å), the blackbody radiation can be considered to be uniform over the bandwidth of the monochromator. Since the bias level is also uniform, a region free of spectral lines can be used to determine the background level. To minimize the effects of noise, the background level was determined by averaging over a 10 Å bandwidth




Figure 4. 6475 Å - 6975 Å spectral sample. Two percent hydrogen added to shield gas.




Figure 5. Expanded hydrogen spectra.

centered at 6800 Å. Before the integrated line intensities were computed, the background level was subtracted from the entire spectrum.

Figure 4 shows that the Stark broadened hydrogen line at 6563 Å extends over a bandwidth of more than 60 Å. To avoid interference from the iron lines at 6546 Å and 6592 Å and the zirconium line at 6569 Å, (see Fig. 8) the hydrogen line integration was limited to ± 3.5 Å about the line peak. Figure 6 is a plot of the integrated line intensity versus hydrogen concentration. Although a generally increasing trend is evident in this plot, it is obvious that good quantitative measurements of the hydrogen concentration cannot be made by measuring just the hydrogen intensity.

The graph of the intensity versus hydrogen concentration clearly shows the need for the normalization procedure discussed earlier. Recall that in this approach the hydrogen line intensity is divided by the intensity of a nearby spectral line. To be effective, intensity variations in the ratioing line should be highly correlated with intensity variations in the hydrogen line. This is extremely important if ratioing is to have the desired effect of removing random variations in the intensity of the hydrogen line.

Table 4 is a list of the correlation coefficients (ρ) between the intensity fluctuations of hydrogen and the major iron and argon lines in the spectrum plotted in Figure 4. The closer the correlation coefficient is to unity, the more highly correlated are variations in the intensity of the two lines. Clearly, the argon line at 6965 Å is the most highly correlated with the hydrogen line. This probably results from two factors. First, the excitation energy of the 6965 Å line is 13.3 eV, and the excitation energy of the 6563 Å hydrogen line is 12.0 eV. Since these values are quite close, the temperature dependence of the two lines is very similar. Second, the argon emissions are due to argon present in the shield gas, while the iron emissions are due to iron vapor from




Figure 6. Hydrogen line intensity versus hydrogen concentration.

TABLE 4
CORRELATION COEFFICIENTS

Element	λ	1% H	2% H
		ρ	ρ
Argon	6965 Å	0.8380	0.900
Argon	6752 Å	0.8264	0.831
Iron	6495 Å	0.0500	0.0183
Iron	6546 Å	0.3451	0.4319
Iron	6593 Å	0.0702	-0.6754
Iron	6678 Å	0.0308	-0.2468

the electrode and base metal. During welding, the shield gas flow rate remains essentially constant which implies that the volume of argon in the weld plasma remains nearly constant. Conversely, metal transfer processes and arc instabilities can vary the volume of iron vapor in the weld plasma considerably. Since argon is a more stable component of the weld plasma than iron vapor, its optical emissions will be more highly correlated with the optical emissions of other plasma components. If we let R denote the ratio of the hydrogen line intensity with the argon line intensity, and $I(\lambda)$ denote the intensity profile of the spectra, the ratio can be expressed as

$$R = \frac{\frac{1}{\Delta h} \int_{\lambda_H - \Delta h/2}^{\lambda_H + \Delta h/2} I(\lambda) d\lambda - \frac{1}{\Delta b} \int_{\lambda_B - \Delta b/2}^{\lambda_B + \Delta b/2} I(\lambda) d\lambda}{\frac{1}{\Delta a} \int_{\lambda_{Ar} - \Delta a/2}^{\lambda_{Ar} + \Delta a/2} I(\lambda) d\lambda - \frac{1}{\Delta b} \int_{\lambda_B - \Delta b/2}^{\lambda_B + \Delta b/2} I(\lambda) d\lambda} \quad (13)$$

where

$$\Delta h = 7.0 \text{ \AA}$$

$$\lambda_H = 6563 \text{ \AA}$$

$$\Delta a = 7.0 \text{ \AA}$$

$$\lambda_{Ar} = 6965 \text{ \AA}$$

$$\Delta b = 10.0 \text{ \AA}$$

$$\lambda_B = 6800 \text{ \AA}$$

A more generalized form of this equation is obtained by multiplying the intensity profile, $I(\lambda)$, by a filter function and integrating over the entire spectra. Equation (13) then becomes

$$R = \frac{\int_{-\infty}^{\infty} I(\lambda) f_H(\lambda) d\lambda - \int_{-\infty}^{\infty} I(\lambda) f_B(\lambda) d\lambda}{\int_{-\infty}^{\infty} I(\lambda) f_{Ar}(\lambda) d\lambda - \int_{-\infty}^{\infty} I(\lambda) f_B(\lambda) d\lambda} \quad (14)$$

where in this case

$$f_H(\lambda) = \begin{cases} \frac{1}{\Delta h} & |\lambda - 6563 \text{ \AA}| \leq \Delta h/2 \\ 0 & \text{elsewhere} \end{cases}$$

$$f_B(\lambda) = \begin{cases} \frac{1}{\Delta b} & |\lambda - 6800 \text{ \AA}| \leq \Delta b/2 \\ 0 & \text{elsewhere} \end{cases}$$

$$f_{Ar}(\lambda) = \begin{cases} \frac{1}{\Delta a} & |\lambda - 6965 \text{ \AA}| \leq \Delta a/2 \\ 0 & \text{elsewhere} \end{cases}$$

D. Results

The intensity ratio given by Equation (14) is plotted versus hydrogen concentration for three separate data sets in Figure 7. It is evident from this plot that the intensity ratio is very nearly a linear function of the hydrogen concentration. A linear regression was used to determine a best-fit line for each data set. The best-fit lines and the coefficients of determination for the three data sets are listed in Table 5. Notice that the regression lines of Table 5 do not pass through the origin. The reason for the offset from zero at the origin can be found by examining the spectrum, plotted in Figure 8, taken with no hydrogen added to the shield gas. The occurrence of a hydrogen emission line clearly indicates that hydrogen exists in the weld plasma. The source of this hydrogen has not been positively identified but is thought to be due to moisture in the gas feed system and hydrogen in the base metal.

The coefficients of determination of the regression lines indicate that the linear fit is quite good, but a definite nonlinear region exists at the lower hydrogen concentrations. This nonlinearity could be attributed to several sources, but the most likely is error in setting the gas flow rates. For




Figure 7. Intensity ratio versus hydrogen concentration.

TABLE 5
LINEAR REGRESSION

DATA SET	SLOPE	INTERCEPT	COEFFICIENT OF DETERMINATION
1	0.7974	0.0283	0.98
2	0.7548	0.0363	0.97
3	0.6819	0.1156	0.97
Combined	0.7501	0.0010	0.97




Figure 8. 6475 Å - 6975 Å spectral sample. No hydrogen added to shield gas.

example, when setting the flow rate for the 0.25% hydrogen mixture, an error of 17% occurs when reading the hydrogen flow rate meter. Other possible sources of nonlinearities are interference from adjacent emission lines and errors in determining the background level.

If the standard deviation of a data set is divided by its mean, the resulting normalized standard deviation provides a measure of the percent error in the data set. Figure 9 is a plot of the normalized standard deviation of the hydrogen ratio versus the hydrogen content of the shield gas. Except for the second data set, the error is well below 10% for most values of hydrogen. The error in the second data set exceeds 10% when the hydrogen concentration exceeds 1.5% of the shield gas. We believe this occurred because a stable arc could not be maintained on this data set at the higher hydrogen levels. Because all of the other data had less than 10% error for hydrogen contents below 1.5%, it appears that the measurement error is on the order of 10%, or less, when measuring the intensity ratio. It may be possible to reduce this error by optimizing the integration time, or by using a more sophisticated filter function.

The stability of the intensity ratio with respect to travel-speed variations is also important if the hydrogen detector is to be used in practical applications. Figure 10 is a plot of the variation of the ratio about the mean versus travel speed for two different hydrogen concentrations. From this plot, it is seen that the error in measuring the ratio is on the order of $\pm 10\%$. It should be noted that from Figure 9 this error is approximately the same error that is expected if travel speed is not varied.

From the preceding analysis it appears that there is a linear relationship between the intensity ratio and the concentration of hydrogen gas in the shield gas mixture. Thus once the best-fit line to a series of test data points has




Figure 9. Ratio error versus hydrogen concentration.




Figure 10. Intensity ratio variation versus travel speed.

been found, the actual hydrogen concentration of an unknown shield gas mixture can be found by substituting the observed intensity ratio into the best-fit line equation. It should be noted that hydrogen introduced from sources other than the shield gas will also be detected and measured by this system.

E. Interference Filter Based H Monitor

The monochromator based hydrogen monitor is an excellent research tool. However, the monochromator, detector array, and computer are expensive. As an alternative, optical interference filters and photodetectors can be used to measure the appropriate line intensities. In an interference filter based system, light from the weld plasma would be passed through each of three filters centered at 6563 Å, 6965 Å, and 6800 Å, respectively, corresponding to the three regions of the spectrum required for hydrogen monitoring. A photodetector positioned behind each interference filter would convert the light intensity to an analog voltage which could then be processed by either simple analog electronics, or a small microprocessor, to compute the hydrogen concentration in the weld plasma.

Optical interference filters are composed of layers of dielectric materials with differing indices of refraction. An interference filter is essentially a series of Fabry Perot interferometers stacked end to end [12]. By controlling the thickness and index of refraction of each layer, it is possible to tailor the transmittance function of the filter. If the bandwidth of the filter is very narrow (less than 10 Å), the filter must be temperature stabilized to prevent drift in the passband. In addition, narrow band filters require the input light to be collimated. These inconveniences can be avoided by working with filters having full width at half maximum (FWHM) bandwidths that are greater

than 10 Å. The transmittance characteristics of an optical interference filter can be modeled as a Gaussian function.

$$f(\lambda) = \frac{1}{\sigma\sqrt{2\pi}} e^{-(\lambda-\lambda_c)/2\sigma^2} \quad (15)$$

where

$$\sigma = \frac{B}{2\sqrt{2 \ln 2}}$$

λ_c = center wavelength

σ = RMS bandwidth

B = FWHM bandwidth

If the uniform filter functions in Equation (14) are replaced with Gaussian filter functions, the operation of the interference filter based hydrogen monitor can be simulated with the spectra used earlier. We assume that the three filters all have the same bandwidth. Systems using filters with bandwidths of 10 Å, 20 Å, 50 Å, and 100 Å FWHM were simulated using data set #1. The intensity ratio, R, is plotted versus hydrogen concentration in Figure 11. Notice that as the filter width is increased, the ratio increases, and nonlinearities become more apparent. These effects occur because as the filter bandwidth increases, interfering lines near the desired hydrogen and argon lines have a greater effect on the ratio. More importantly, from the plot of the normalized standard deviation shown in Figure 12, we see that the error increases significantly as the filter FWHM width is increased. From Figures 11 and 12 it appears that filter bandwidths of between 10 Å and 20 Å FWHM should result in a hydrogen monitor which performs almost as well as the monochromator based hydrogen system.




Figure 11. Intensity ratio versus hydrogen concentration.




Figure 12. Ratio error versus filter bandwidth.

V. CONCLUSIONS

The spectroscopic technique described in this paper is capable of measuring the absolute hydrogen concentration in weld arc plasmas at concentration levels which have been shown to cause weld failure (0.1 - 0.2% of the shield gas). The measurement accuracy is approximately 10%. Since the method is a real-time technique, hydrogen contamination problems can be spotted and corrected as the weld is being made, thus reducing costly rework. The cost of the interference filter based hydrogen monitor should be low enough to allow its general use when welding steels which are susceptible to hydrogen embrittlement.

Although our experiments were conducted by mixing known concentrations of hydrogen gas with the shield gas, this spectroscopic technique will measure the hydrogen from all sources including water and lubricants. It should also be possible to adapt the technique to other welding configurations which use different shield gasses or flux bearing electrodes. If argon is not present in the shield gas, an emission line from a different element will have to be used to normalize the hydrogen line intensity. This will result in a different relation between the intensity ratio and hydrogen concentration. However, by properly choosing the normalizing line, it should be possible to obtain a nearly linear variation of the line ratio with respect to hydrogen concentration.

The same spectroscopic techniques developed for detecting hydrogen can also be used for detecting many other impurities which affect weld quality. For example, by tuning the monochromator to a prominent oxygen spectral line, we have detected oxygen contamination in titanium welding. The system has also been used to detect loss of shield gas [4] and to detect flux voids while welding with flux core electrodes.

In summary, the optical techniques described in this paper provide an effective research tool for studying the physics and chemistry of welding, while at the same time offer the prospect of improved weld quality and, hence, reduced cost in commercial welding.

APPENDIX A

SIGNAL PROCESSING SOFTWARE

- A.1. Main Program
- A.2. Correlation Routine
- A.3. Integration Function
- A.4. Filter Function
- A.5. Disk Read Routine

A.1. Main Program

```

C*****
C      PROGRAM SPSTAT                                *
C      BY JIM SHEA          AUGUST 3,1982           *
C                                                    *
C      THIS PROGRAM CALCULATES THE STATISTICS AND RATIOS OF *
C      SPECTRAL DATA. IT WILL RATIO ONE LINE WITH UP TO *
C      FOUR OTHER LINES                                *
C                                                    *
C*****
C      VARIABLES:                                     *
C      IDATA  INTEGER ARRAY USED TO HOLD A DATA SCAN. *
C                                                    *
C      BAKDIO: THE BACKGROUND DIODE NUMBER.           *
C      INTBAK: NUMBER OF DIODES INTEGRATED ABOUT THE *
C      BACKGROUND                                     *
C                                                    *
C      LINDIO: THE LINE DIODE NUMBER.                *
C      INTLIN: NUMBER OF DIODES INTEGRATED ABOUT THE *
C      LINE DIODE.                                    *
C                                                    *
C      RATDIO: ARRAY USED TO HOLD THE FOUR RATIO DIODES. *
C      INTRAT: ARRAY USED TO HOLD THE NUMBER OF DIODES *
C      INTEGRATED ABOUT THE RATIO DIODE.             *
C                                                    *
C*****
C
C      COMMON/ARRAY/IDATA
C      INTEGER INTDIO,INTLIN,INTRAT(4)
C      INTEGER IDATA(1024),BAKDIO,LINDIO,RATDIO(4)
C
C      BYTE LFILE(6)
C
C      REAL INTEG,BACKGN(100),LINE(100),TEMP(100),RATIO(4,100)
C      REAL MEAN1,MEAN2(4),STD1,STD2(4),RI(4),MEANL,MEANS
C      REAL RMEAN(4),RSTD(4),MEAN,STD,MAXRAT(4),MINRAT(4)
C
C
C      SET THE REGION OF THE SPECTRUM TO BE USED FOR
C      THE BACKGROUND CALCULATION
C
C      BAKDIO=920
C      INTBAK=10
C
C      GET THE FILE NAME
C
C      TYPE 100
100  FORMAT('/' ENTER THE FILE NAME: '$)
      ACCEPT 200,(LFILE(I),I=1,6)
200  FORMAT(6A1)
C

```



```

C      GET THE DIODE NUMBER OF THE WAVELENGTH OF INTEREST
C
      TYPE 101
101    FORMAT(/' ENTER THE DIODE NUMBER OF THE LINE OF INTEREST:'$)
      ACCEPT 201,LINDIO
201    FORMAT(I4)
      TYPE 102
102    FORMAT(' HOW MANY DIODES SHOULD BE INTEGRATED ON EITHER SIDE ',
X      ' OF THE LINE:'$)
      ACCEPT 202,INTLIN
202    FORMAT(I4)
C
C
C      GET THE LINES TO BE USED FOR AVERAGING. UP TO FOUR
C      LINES MAY BE USED. DATA ENTRY IS STOPPED WHEN A
C      RETURN IS ENTERED WITHOUT ANY DATA.
C
      TYPE 103
103    FORMAT(/' ENTER THE DIODE NUMBERS OF THE LINES TO BE',
X      ' USED FOR AVERAGING. '//, ' TO STOP DATA ENTRY ENTER',
X      ' A RETURN')
      NUMRAT=0
10    NUMRAT=NUMRAT+1
      TYPE 104,NUMRAT
104    FORMAT(' RATIO DIODE NUMBER',I2,':'$)
      ACCEPT 203,RATDIO(NUMRAT)
203    FORMAT(I4)
      IF(RATDIO(NUMRAT).EQ.0) GO TO 22
      TYPE 300
300    FORMAT(' NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE',
X      ' OF THE LINE :'$)
      ACCEPT 400,INTRAT(NUMRAT)
400    FORMAT(I4)
22    IF((NUMRAT.NE.4).AND.(RATDIO(NUMRAT).NE.0)) GO TO 10
      IF(NUMRAT.NE.4)NUMRAT=NUMRAT-1
      IF((NUMRAT.EQ.4).AND.(RATDIO(4).EQ.0)) NUMRAT=3
C
C
C      SEE IF THE BACKGROUND REGION SHOULD BE CHANGED
C
      TYPE 1000
1000   FORMAT(/' DO YOU WANT TO USE A NON-DEFAULT BACKGROUND REGION :'$)
      ACCEPT 1001,IBAK
1001   FORMAT(A1)
      IF(IBAK.NE.'Y') GO TO 500
      TYPE 1002
1002   FORMAT(' ENTER THE BACKGROUND DIODE NUMBER:'$)
      ACCEPT 1003,BAKDIO
1003   FORMAT(I4)
      TYPE 1004
1004   FORMAT(' ENTER INTEGRATION RANGE:'$)
      ACCEPT 1003,INTBAK

```

```

C
C      EXTRACT THE DATA FROM THE FILE
C
600   ISCAN=1
20    CALL READIT(LFILE,ISCAN-1,IDATA,FILEND)
      IF(FILEND.EQ.0.) GO TO 30
      CALL CONV(IDATA)
      BACKGN(ISCAN)=INTEG(BAKDIO,INTBAK)
      LINE(ISCAN)=INTEG(LINDIO,INTLIN)
      DO 25 I=1,NUMRAT
        RATIO(I,ISCAN)=INTEG(RATDIO(I),INTRAT(I))
25    CONTINUE
      ISCAN=ISCAN+1
      GO TO 20
30    ISCAN=ISCAN-1
C
C
C***** SUBTRACT THE BIAS *****
C
C
      DO 700 I=1,ISCAN
        LINE(I)=LINE(I)-BACKGN(I)
        IF(LINE(I).LT.0.) TYPE 701,I-1
701    FORMAT(' LINE WENT BELOW BACKGROUND ON SCAN',I3)
        DO 900 J=1,NUMRAT
          RATIO(J,I)=RATIO(J,I)-BACKGN(I)
          IF(RATIO(J,I).LT.0.) TYPE 702,J,I-1
702    FORMAT(' RATIO LINE DIODE NUM',I4,' WENT BELOW BACK',
X      'GROUND ON SCAN',I3)
800    CONTINUE
700    CONTINUE
C
C      CALCULATE THE STATISTICS AND RATIOS
C
      DO 50 I=1,NUMRAT
        DO 70 J=1,ISCAN
          TEMP(J)=RATIO(I,J)
70    CONTINUE
        CALL CORREL(ISCAN,LINE,TEMP,MEAN1,MEAN2(I),STD1,STD2(I),RI(I))
50    CONTINUE
        CALL CORREL(ISCAN,LINE,BACKGN,MEANL,MEANB,STDL,STDB,R)
C
C
C      CALCULATE RATIOED MEANS AND STANDARD DEVIATIONS
C
      DO 80 I=1,NUMRAT
        DO 95 J=1,ISCAN
          RATIO(I,J)=LINE(J)/RATIO(I,J)
85    CONTINUE
        DO 900 K=1,ISCAN
          TEMP(K)=RATIO(I,K)
900    CONTINUE

```

```

      CALL CORREL(ISCAN,LINE,TEMP,MEAN,RMEAN(I),STD,RSTD(I),RJUNK)
80  CONTINUE
C
C  FIND THE MAXIMUM AND MINIMUM VALUE OF THE RATIOED DATA
C
DO 601 I=1,NUMRAT
  MAXRAT(I)=0.
  MINRAT(I)=100000.
  DO 610 J=1,ISCAN
    IF(MAXRAT(I).LT.RATIO(I,J)) MAXRAT(I)=RATIO(I,J)
    IF(MINRAT(I).GT.RATIO(I,J)) MINRAT(I)=RATIO(I,J)
610  CONTINUE
501  CONTINUE
C
C  DISPLAY THIS WONDERFUL DATA
C
C
TYPE 110
110  FORMAT(// '***** UNRATIOED STATISTICS *****')
TYPE 111,MEANL
111  FORMAT('      MEAN OF LINE OF INTEREST :',F9.3)
TYPE 112,STD1
112  FORMAT('      STANDARD DEVIATION OF LINE OF INTEREST :',F8.3)
TYPE 412,STD1/MEANL
412  FORMAT('      NORMALIZED STANDARD DEVIATION :',F8.4)
TYPE 113
113  FORMAT(' STATISTICS OF LINES USED FOR RATIOING')
TYPE 114,(RATDIO(I),I=1,NUMRAT)
114  FORMAT('      DIODE NUMBER OF RATIO LINE',I8,3I12)
TYPE 115,(MEAN2(I),I=1,NUMRAT)
115  FORMAT(10X,'      MEAN',F9.3,3F12.3)
TYPE 116,(STD2(I),I=1,NUMRAT)
116  FORMAT(10X,'      STANDARD DEVIATION',F9.3,3F12.3)
TYPE 416,(STD2(I)/MEAN2(I),I=1,NUMRAT)
416  FORMAT(3X,'      NORMALIZED STANDARD DEVIATION',F8.4,3F12.4)
TYPE 117,(RI(I),I=1,NUMRAT)
117  FORMAT(10X,'CORRELATION COEFFICIENT',F8.4,3F12.4)
TYPE 118
118  FORMAT(// '***** RATIOED DATA *****')
TYPE 119,(RATDIO(I),I=1,NUMRAT)
119  FORMAT('      DIODE NUMBER OF RATIO LINE:',I8,3I12)
TYPE 620,(MAXRAT(I),I=1,NUMRAT)
620  FORMAT(4X,'      MAXIMUM OF THE RATIOS:',F8.4,3F12.4)
TYPE 630,(MINRAT(I),I=1,NUMRAT)
630  FORMAT(4X,'      MINIMUM OF THE RATIOS:',F8.4,3F12.4)
TYPE 120,(RMEAN(I),I=1,NUMRAT)
120  FORMAT(4X,'      MEAN',F8.4,3F12.4)
TYPE 121,(RSTD(I),I=1,NUMRAT)
121  FORMAT(4X,'      STANDARD DEVIATION',F8.4,3F12.4)
TYPE 421,((RSTD(I)/RMEAN(I)),I=1,NUMRAT)
421  FORMAT('      NORMALIZED STANDARD DEVIATION',F6.4,3F12.4)

```

```
C
C
C   SEE IF THE DATA SHOULD BE GATHERED ON A DIFFERENT FILE
C
TYPE 130
130  FORMAT(/' DO YOU WANT TO CALCULATE THESE STATISTICS FOR A ',
X    'DIFFERENT FILE? 'S)
ACCEPT 230, IANS
230  FORMAT(A1)
     IF(IANS.NE.'Y') GO TO 300
TYPE 140
140  FORMAT(' ENTER THE FILE NAME: 'S)
ACCEPT 240, (LFILE(I), I=1,6)
240  FORMAT(6A1)
     GO TO 600
500  CALL EXIT
     END
```

A.2. Correlation Routine

```

C*****
C
C      SUBROUTINE CORREL
C
C      BY JIM SHEA      AUGUST 5,1982
C*****
C
C      THIS SUBROUTINE PERFORMS A CORRELATION ON A DATA
C      SET OF UP TO 100 POINTS. IT RETURNS THE CORRELATION
C      COEFFICIENT, MEANS, AND STANDARD DEVIATIONS.
C*****
C
C      SUBROUTINE CORREL(N,ARRAY1,ARRAY2,MEAN1,MEAN2,STD1,STD2,R)
C      REAL X,Y,XY,X2,Y2,ARRAY1(100),ARRAY2(100)
C      REAL MEAN1,MEAN2
C
C      X=0.
C      Y=0.
C      XY=0.
C      X2=0.
C      Y2=0.
C
C      DO 10 I=1,N
C          X=ARRAY1(I)+X
C          Y=ARRAY2(I)+Y
C          XY=ARRAY1(I)*ARRAY2(I)+XY
C          X2=ARRAY1(I)**2+X2
C          Y2=ARRAY2(I)**2+Y2
10      CONTINUE
C      SCAN=FLOAT(N)
C      MEAN1=X/SCAN
C      MEAN2=Y/SCAN
C      STD1=SGRT((X2-X**2/SCAN)/(SCAN-1.))
C      STD2=SGRT((Y2-Y**2/SCAN)/(SCAN-1.))
C      R=(XY-(X*Y)/SCAN)/(SCAN-1.)
C      IF STD1=0 OR STD2=0 WE HAVE A DETERMINISTIC SYSTEM.
C      IF((STD1.LT.1E-10).OR.(STD2.LT.1E-10)) GO TO 20
C      R=R/(STD1*STD2)
C      RETURN
20      R=10
C      RETURN
C      END

```

A.3. Integration Function

```
C*****
C
C      FUNCTION SUBROUTINE INTEG
C
C              BY JIM SHEA AUGUST 5, 1982
C*****
C
C      THIS FUNCTION INTEGRATES THE DIODES AND RETURNS A REAL
C      RESULT.
C
C      REAL FUNCTION INTEG(CNTR,INT)
C      INTEGER INT,CNTR, IDATA(1024)
C      COMMON/ARRAY/IDATA
C
C      IF((CNTR-12).GT.INT) GO TO 10
C      TYPE 100
100    FORMAT(' INTEGRATION ERROR')
C
10      INTEG=0.
      DO 20 I=(CNTR-INT), (CNTR+INT)
          INTEG=INTEG+FLOAT(IDATA(I))
20      CONTINUE
      INTEG=INTEG/FLOAT(2*INT+1)
      RETURN
      END
```

A.4. Filter Function

```

C*****
C
C      FUNCTION SUBROUTINE INTEG
C
C              BY JIM SHEA AUGUST 5, 1982
C*****
C
C      THIS FUNCTION APPLIES A GAUSSIAN FILTER TO THE DIODES
C      AND RETURNS A REAL RESULT.
C
C      REAL FUNCTION INTEG(CNTR,FWHM)
C      INTEGER INT,CNTR, IDATA(1024),BAKDIO
C      COMMON/ARRAY/IDATA
C      COMMON/NOSP/BAKDIO
C
C      CALCULATE SIGMA IN ANGSTROMS
C
C      SIGMA=FWHM/2.354
C      INTEG=0.
C      DO 10 I=CNTR-6*IFIX(SIGMA),CNTR+6*IFIX(SIGMA)
C          TEMP=(FLOAT(I-CNTR)*.52)**2/(2.*(SIGMA**2))
C          TEMP*.39894*(1./SIGMA)*EXP(-TEMP)
C          IF((I.LT.12).OR.(I.GT.1023)) GO TO 20
C          INTEG=INTEG+IDATA(I)*TEMP
C          GO TO 10
C      20    INTEG=INTEG+IDATA(BAKDIO)*TEMP
C      10    CONTINUE
C          RETURN
C          END

```

A.5. Disk Read Routine

```

SUBROUTINE READIT (LFILE,SCAN,IDATA,FILEND)
C THIS SUBROUTINE READS A FILE FROM DISK.
  INTEGER SCAN,DBLK(4),IDATA(1024)
  BYTE LFILE(6)
C
  DATA IDNAM/2RDM/
  DATA DBLK(1)/3RDM1/,DBLK(4)/3RDAT/
C
  FILEND=1.
C
C CALCULATE BLOCK NUMBER FROM SCAN NUMBER.
  ISCAN=SCAN*4
  CALL IRADSO(6,LFILE,DBLK(2))
C GET THE DISK HANDLER
  IF(IFETCH(IDNAM).NE.0) STOP 'FETCH ERROR'
C ALLOCATE CHANNEL FOR DATA TRANSFER.
  ICHAN=IGETC()
C CHECK FOR CHANNEL ALLOCATION ERROR
  IF(ICHAN.LT.0) STOP 'CHANNEL ALLOCATION ERROR'
C FIND THE FILE IN THE DISK
  IF(LOOKUP(ICHAN,DBLK).LT.0) STOP 'LOOKUP ERROR'
C
C READ THE FILE AND STORE IT IN IDATA AND CHECK FOR ERRORS
  IF(IREADW(1024,IDATA,ISCAN,ICHAN).LT.0) GO TO 10
C
C CLOSE THE CHANNEL
  CALL CLOSEC(ICHAN)
  CALL IFREEC(ICHAN)
C
  RETURN
C
C SET FILEND (END OF DATA TO 0)
10 FILEND=0.
  CALL CLOSEC(ICHAN)
  CALL IFREEC(ICHAN)
  RETURN
  END
C
C -----
C
C SUBROUTINE CONV(IDATA)
C THIS SUBROUTINE CONVERTS DATA FROM THE ADAC A/D REPRESENTATION
C TO INTEGER FORMAT.
C
C SUBROUTINE CONV(IDATA)
C
C INTEGER*2 IDATA(1024)
C
C DO 10 I=12,1024
  IDATA(I)=-IDATA(I)/IDATA(7)*4.98

```



```
10      IF(IDATA(I).LE.0) IDATA(I)=IDATA(I)+4096*4.88  
      CONTINUE  
      RETURN  
      END
```

APPENDIX B

STATISTICAL ANALYSIS OF SPECTRAL DATA

- B.1. Variation of Hydrogen Concentration in Shield Gas
 - B.1.1. Data Set No. 1
 - B.1.2. Data Set No. 2
 - B.1.3. Data Set No. 3
- B.2. Variation of Travel Speed
 - B.2.1. 1 Percent Hydrogen
 - B.2.2. 0.5 Percent Hydrogen
- B.3. Filter Simulation on Data Set No. 1
 - B.3.1. 10 Å Filter
 - B.3.2. 20 Å Filter
 - B.3.3. 50 Å Filter
 - B.3.4. 100 Å Filter

B.1. Variation of Hydrogen Concentration in Shield Gas

B.1.1. Data Set No. 1

File Name	Hydrogen Concentration (%)
HD00	0.00
HD01	0.25
HD02	0.50
HD03	0.75
HD04	1.00
HD05	1.25
HD06	1.50
HD07	1.75
HD08	2.00
HD09	2.25
HD10	2.50
HD11	2.75
HD12	3.00

Element	Wavelength (\AA)	Diode Number
Iron	6494.98	77
Hydrogen	6563.82	204
Iron	6677.99	421
Argon	6752.83	564
Argon	6965.43	974

.RUN MANYSP

ENTER THE FILE NAME: HD

ENTER THE DIODE NUMBER OF THE LINE OF INTEREST:204
 HOW MANY DIODES SHOULD BE INTEGRATED ON EITHER SIDE OF THE LINE:7

ENTER THE DIODE NUMBERS OF THE LINES TO BE USED FOR AVERAGING.
 TO STOP DATA ENTRY ENTER A RETURN

RATIO DIODE NUMBER 1:364
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 RATIO DIODE NUMBER 2:974
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 RATIO DIODE NUMBER 3:77
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 RATIO DIODE NUMBER 4:421
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 DO YOU WANT TO USE A NON-STANDARD BACKGROUND REGION :Y
 ENTER THE BACKGROUND DIODE NUMBER:625
 ENTER THE NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE:10

FILE NAME : HD00

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 137.775
 STANDARD DEVIATION OF LINE OF INTEREST : 12.867
 NORMALIZED STANDARD DEVIATION : 0.0934
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	364	974	77	421
MEAN	93.061	611.964	249.497	103.909
STANDARD DEVIATION	7.824	42.251	31.049	20.807
NORMALIZED STANDARD DEVIATION	0.0841	0.0690	0.2046	0.2002
CORRELATION COEFFICIENT	0.7665	0.6583	0.6772	0.7207

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	364	974	77	421
MAXIMUM OF THE RATIOS:	1.7362	0.2674	0.7925	1.7910
MINIMUM OF THE RATIOS:	1.2987	0.1941	0.4167	1.0086
MEAN	1.4817	0.2253	0.5694	1.3644
STANDARD DEVIATION	0.0914	0.0167	0.0946	0.2157
NORMALIZED STANDARD DEVIATION	0.0617	0.0740	0.1661	0.1581

FILE NAME : HD01

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 299.327
 STANDARD DEVIATION OF LINE OF INTEREST : 26.166
 NORMALIZED STANDARD DEVIATION : 0.0874

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	160.956	938.247	383.171	153.339
STANDARD DEVIATION	11.304	68.115	73.302	29.000
NORMALIZED STANDARD DEVIATION	0.0702	0.0726	0.1913	0.1891
CORRELATION COEFFICIENT	0.8777	0.6921	-0.6336	-0.5997

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	2.0739	0.4050	1.6558	4.0938
MINIMUM OF THE RATIOS:	1.6460	0.2764	0.5052	1.3064
MEAN	1.8589	0.3193	0.8213	2.0569
STANDARD DEVIATION	0.0803	0.0218	0.2312	0.6073
NORMALIZED STANDARD DEVIATION	0.0432	0.0683	0.2814	0.2952

FILE NAME : HD02

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 283.828
 STANDARD DEVIATION OF LINE OF INTEREST : 20.839
 NORMALIZED STANDARD DEVIATION : 0.0734

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	111.560	701.944	328.752	135.580
STANDARD DEVIATION	7.905	50.596	53.986	19.980
NORMALIZED STANDARD DEVIATION	0.0709	0.0721	0.1642	0.1474
CORRELATION COEFFICIENT	0.8961	0.7812	0.2227	0.2569

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	2.8039	0.4513	1.2380	2.8484
MINIMUM OF THE RATIOS:	2.3933	0.3647	0.6245	1.5541
MEAN	2.5451	0.4047	0.8847	2.1332
STANDARD DEVIATION	0.0841	0.0197	0.1490	0.3173
NORMALIZED STANDARD DEVIATION	0.0331	0.0488	0.1684	0.1488

FILE NAME : HD03

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 384.708
 STANDARD DEVIATION OF LINE OF INTEREST : 34.348
 NORMALIZED STANDARD DEVIATION : 0.0893
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	120.015	775.598	313.426	130.207
STANDARD DEVIATION	9.174	48.915	31.066	13.248
NORMALIZED STANDARD DEVIATION	0.0764	0.0631	0.0991	0.1017
CORRELATION COEFFICIENT	0.8157	0.7546	0.4136	0.3024

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	4.0774	0.6380	1.4461	3.7367
MINIMUM OF THE RATIOS:	2.9218	0.4537	0.9341	2.1990
MEAN	3.2063	0.4959	1.2344	2.9757
STANDARD DEVIATION	0.1697	0.0299	0.1203	0.3274
NORMALIZED STANDARD DEVIATION	0.0529	0.0603	0.0975	0.1100

FILE NAME : HD04

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 707.399
 STANDARD DEVIATION OF LINE OF INTEREST : 63.945
 NORMALIZED STANDARD DEVIATION : 0.0904
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	163.369	973.485	323.460	133.690
STANDARD DEVIATION	11.843	76.782	62.781	26.377
NORMALIZED STANDARD DEVIATION	0.0725	0.0789	0.1941	0.1988
CORRELATION COEFFICIENT	0.7332	0.5033	-0.6256	-0.4844

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	5.4433	1.0194	3.6516	3.3753
MINIMUM OF THE RATIOS:	3.8280	0.6124	1.0487	2.4026
MEAN	4.3331	0.7292	2.2931	5.5513
STANDARD DEVIATION	0.2879	0.0684	0.5746	1.3720
NORMALIZED STANDARD DEVIATION	0.0664	0.0938	0.2506	0.2472

FILE NAME : HD05

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 719.343
 STANDARD DEVIATION OF LINE OF INTEREST : 32.358
 NORMALIZED STANDARD DEVIATION : 0.0453
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	136.437	860.171	311.285	131.487
STANDARD DEVIATION	7.519	36.887	31.006	12.918
NORMALIZED STANDARD DEVIATION	0.0558	0.0429	0.0996	0.0982
CORRELATION COEFFICIENT	0.5638	0.4343	0.3449	0.2697

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	6.1413	0.9938	2.9647	6.7995
MINIMUM OF THE RATIOS:	4.7482	0.7586	1.9199	4.5620
MEAN	3.2816	0.8372	2.3306	3.5183
STANDARD DEVIATION	0.2610	0.0408	0.2264	0.3518
NORMALIZED STANDARD DEVIATION	0.0494	0.0487	0.0972	0.1000

FILE NAME : HD06

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 675.676
 STANDARD DEVIATION OF LINE OF INTEREST : 58.541
 NORMALIZED STANDARD DEVIATION : 0.0866
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	121.131	650.846	498.933	206.711
STANDARD DEVIATION	9.188	55.633	35.695	17.631
NORMALIZED STANDARD DEVIATION	0.0758	0.0855	0.0715	0.0853
CORRELATION COEFFICIENT	0.8829	0.8894	-0.0755	-0.0056

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	6.3006	1.1237	2.0455	4.9929
MINIMUM OF THE RATIOS:	5.2092	0.9505	1.1064	2.7469
MEAN	5.5777	1.0389	1.3625	3.2949
STANDARD DEVIATION	0.2251	0.0417	0.1730	0.4439
NORMALIZED STANDARD DEVIATION	0.0404	0.0402	0.1270	0.1347

FILE NAME : HD07

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 704.242
 STANDARD DEVIATION OF LINE OF INTEREST : 69.095
 NORMALIZED STANDARD DEVIATION : 0.0981
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	101.851	554.259	432.321	172.825
STANDARD DEVIATION	10.450	61.511	38.370	16.802
NORMALIZED STANDARD DEVIATION	0.1026	0.1110	0.0888	0.0972
CORRELATION COEFFICIENT	0.3470	0.9402	-0.0454	0.0465

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	7.9334	1.4020	2.4874	6.1464
MINIMUM OF THE RATIOS:	6.0349	1.1856	1.1782	2.9515
MEAN	6.9289	1.2733	1.6421	4.1106
STANDARD DEVIATION	0.3896	0.0506	0.2241	0.5586
NORMALIZED STANDARD DEVIATION	0.0562	0.0398	0.1365	0.1359

FILE NAME : HD08

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 857.252
 STANDARD DEVIATION OF LINE OF INTEREST : 72.032
 NORMALIZED STANDARD DEVIATION : 0.0840
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	97.065	543.973	400.770	160.923
STANDARD DEVIATION	11.677	70.072	46.928	22.841
NORMALIZED STANDARD DEVIATION	0.1203	0.1288	0.1171	0.1419
CORRELATION COEFFICIENT	0.6542	0.7027	0.1758	0.2447

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	11.1584	2.0253	3.0207	7.2348
MINIMUM OF THE RATIOS:	7.3677	1.3819	1.6314	3.7502
MEAN	8.9034	1.5912	2.1653	5.4212
STANDARD DEVIATION	0.3487	0.1592	0.2943	0.8176
NORMALIZED STANDARD DEVIATION	0.0933	0.1001	0.1359	0.1508

FILE NAME : HD09

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 888.800
 STANDARD DEVIATION OF LINE OF INTEREST : 130.986
 NORMALIZED STANDARD DEVIATION : 0.1474
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	96.412	503.994	319.554	147.177
STANDARD DEVIATION	15.616	83.887	53.164	21.916
NORMALIZED STANDARD DEVIATION	0.1807	0.1664	0.1664	0.1748
CORRELATION COEFFICIENT	0.8758	0.9191	0.4934	0.5143

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	13.1722	2.0226	4.0447	10.0063
MINIMUM OF THE RATIOS:	8.7826	1.5802	2.1169	5.3944
MEAN	10.3947	1.7727	2.8225	7.2385
STANDARD DEVIATION	0.9587	0.1142	0.4538	1.1534
NORMALIZED STANDARD DEVIATION	0.0922	0.1608	0.1608	0.1593

FILE NAME : HD10

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 1091.270
 STANDARD DEVIATION OF LINE OF INTEREST : 154.739
 NORMALIZED STANDARD DEVIATION : 0.1418
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	98.122	554.735	386.627	154.668
STANDARD DEVIATION	13.934	81.129	51.702	24.302
NORMALIZED STANDARD DEVIATION	0.1420	0.1462	0.1337	0.1571
CORRELATION COEFFICIENT	0.8825	0.9293	0.1680	0.2175

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	13.2840	2.2976	3.7824	9.8355
MINIMUM OF THE RATIOS:	9.3293	1.7646	2.0492	5.0651
MEAN	11.1531	1.9724	2.8678	7.2057
STANDARD DEVIATION	0.7643	0.1112	0.5197	1.3864
NORMALIZED STANDARD DEVIATION	0.0685	0.0564	0.1812	0.1924

FILE NAME : HD11

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST :1144.680
 STANDARD DEVIATION OF LINE OF INTEREST : 167.743
 NORMALIZED STANDARD DEVIATION : 0.1463
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	86.662	520.158	299.674	118.789
STANDARD DEVIATION	13.165	89.891	29.701	13.436
NORMALIZED STANDARD DEVIATION	0.1519	0.1728	0.0991	0.1131
CORRELATION COEFFICIENT	0.9360	0.9196	0.2692	0.3885

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	15.5657	2.8605	5.1697	12.4413
MINIMUM OF THE RATIOS:	11.6925	1.9404	2.7450	7.2993
MEAN	13.2429	2.2150	3.8413	9.6981
STANDARD DEVIATION	0.7699	0.1642	0.5738	1.3990
NORMALIZED STANDARD DEVIATION	0.0581	0.0741	0.1494	0.1443

FILE NAME : HD12

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST :1442.935
 STANDARD DEVIATION OF LINE OF INTEREST : 169.586
 NORMALIZED STANDARD DEVIATION : 0.1175
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974	77	421
MEAN	108.956	623.079	418.244	175.411
STANDARD DEVIATION	12.825	80.844	37.237	17.298
NORMALIZED STANDARD DEVIATION	0.1177	0.1297	0.0890	0.0986
CORRELATION COEFFICIENT	0.9330	0.9503	0.4447	0.5345

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974	77	421
MAXIMUM OF THE RATIOS:	14.6190	2.5696	4.3395	10.1174
MINIMUM OF THE RATIOS:	12.0312	2.0881	2.7890	6.5569
MEAN	13.2577	2.3220	3.4603	8.2534
STANDARD DEVIATION	0.5678	0.0987	0.3924	0.8847
NORMALIZED STANDARD DEVIATION	0.0423	0.0425	0.1134	0.1072

B.1.2. Data Set No. 2

File Name	Hydrogen Concentration (%)
HL00	0.00
HL01	0.25
HL02	0.50
HL03	0.75
HL04	1.00
HL05	1.25
HL06	1.50
HL07	1.75
HL08	2.00
HL09	2.25
HL10	2.50
HL11	2.75
HL12	3.00

Element	Wavelength (Å)	Diode Number
Iron	6494.98	77
Hydrogen	6563.82	204
Iron	6677.99	421
Argon	6752.83	562
Argon	6965.43	972

.RUN MANYSP

ENTER THE FILE NAME: HL

ENTER THE DIODE NUMBER OF THE LINE OF INTEREST:204
 HOW MANY DIODES SHOULD BE INTEGRATED ON EITHER SIDE OF THE LINE:7

ENTER THE DIODE NUMBERS OF THE LINES TO BE USED FOR AVERAGING.
 TO STOP DATA ENTRY ENTER A RETURN

RATIO DIODE NUMBER 1:562
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 RATIO DIODE NUMBER 2:972
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 RATIO DIODE NUMBER 3:77
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 RATIO DIODE NUMBER 4:421
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 DO YOU WANT TO USE A NON-STANDARD BACKGROUND REGION :Y
 ENTER THE BACKGROUND DIODE NUMBER:623
 ENTER THE NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE:10

FILE NAME : HLOO

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 86.082
 STANDARD DEVIATION OF LINE OF INTEREST : 12.453
 NORMALIZED STANDARD DEVIATION : 0.1447

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	83.746	631.363	194.993	76.639
STANDARD DEVIATION	11.808	70.247	48.430	19.283
NORMALIZED STANDARD DEVIATION	0.1410	0.1113	0.2484	0.2516
CORRELATION COEFFICIENT	0.8724	0.7955	0.6196	0.6460

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	1.1928	0.1641	0.7077	1.9388
MINIMUM OF THE RATIOS:	0.8687	0.1100	0.2873	0.7142
MEAN	1.0299	0.1363	0.4592	1.1701
STANDARD DEVIATION	0.0758	0.0120	0.0921	0.2395
NORMALIZED STANDARD DEVIATION	0.0736	0.0878	0.2006	0.2047

FILE NAME : HLO1

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 145.070

STANDARD DEVIATION OF LINE OF INTEREST : 16.737

NORMALIZED STANDARD DEVIATION : 0.1154

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	80.278	556.308	292.532	76.840
STANDARD DEVIATION	8.797	52.678	63.319	23.816
NORMALIZED STANDARD DEVIATION	0.1096	0.0947	0.2241	0.2459
CORRELATION COEFFICIENT	0.9235	0.7821	0.4509	0.5234

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	2.0187	0.2983	0.9574	2.7472
MINIMUM OF THE RATIOS:	1.6462	0.2187	0.3591	1.0709
MEAN	1.8077	0.2609	0.5348	1.5735
STANDARD DEVIATION	0.0827	0.0188	0.1175	0.3695
NORMALIZED STANDARD DEVIATION	0.0457	0.0720	0.2197	0.2348

FILE NAME : HLO2

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 216.054

STANDARD DEVIATION OF LINE OF INTEREST : 26.677

NORMALIZED STANDARD DEVIATION : 0.1233

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	85.230	592.179	317.886	109.479
STANDARD DEVIATION	9.307	64.646	48.107	19.229
NORMALIZED STANDARD DEVIATION	0.1092	0.1110	0.1513	0.1756
CORRELATION COEFFICIENT	0.8858	0.8070	0.2330	0.3285

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	2.9418	0.4262	1.1194	3.1865
MINIMUM OF THE RATIOS:	2.2409	0.3188	0.5095	1.4504
MEAN	2.5349	0.3716	0.6926	2.0194
STANDARD DEVIATION	0.1450	0.0282	0.1293	0.3746
NORMALIZED STANDARD DEVIATION	0.0572	0.0760	0.1867	0.1855

FILE NAME : HLO3

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 282.401
 STANDARD DEVIATION OF LINE OF INTEREST : 36.632
 NORMALIZED STANDARD DEVIATION : 0.1297

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	88.853	549.199	421.428	148.776
STANDARD DEVIATION	11.833	68.751	70.971	27.753
NORMALIZED STANDARD DEVIATION	0.1332	0.1252	0.1684	0.1865
CORRELATION COEFFICIENT	0.9426	0.9235	0.7088	0.7092

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	3.5192	0.5898	0.9306	2.9945
MINIMUM OF THE RATIOS:	2.8564	0.4729	0.5714	1.5315
MEAN	3.1820	0.5144	0.6794	1.9365
STANDARD DEVIATION	0.1413	0.0258	0.0916	0.3046
NORMALIZED STANDARD DEVIATION	0.0444	0.0501	0.1349	0.1573

FILE NAME : HLO4

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 314.233
 STANDARD DEVIATION OF LINE OF INTEREST : 35.860
 NORMALIZED STANDARD DEVIATION : 0.1141

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	74.593	471.224	331.594	114.321
STANDARD DEVIATION	6.880	48.207	49.586	21.004
NORMALIZED STANDARD DEVIATION	0.0922	0.1023	0.1495	0.1837
CORRELATION COEFFICIENT	0.8351	0.8399	0.0842	0.0482

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	4.8824	0.7670	1.7723	4.8750
MINIMUM OF THE RATIOS:	3.7327	0.5758	0.7391	1.9661
MEAN	4.2114	0.6671	0.9699	2.8469
STANDARD DEVIATION	0.2602	0.0391	0.2031	0.6779
NORMALIZED STANDARD DEVIATION	0.0618	0.0586	0.2094	0.2381

FILE NAME : HL05

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 409.948

STANDARD DEVIATION OF LINE OF INTEREST : 59.739

NORMALIZED STANDARD DEVIATION : 0.1457

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	78.168	490.357	347.849	123.041
STANDARD DEVIATION	10.286	64.202	68.152	26.108
NORMALIZED STANDARD DEVIATION	0.1316	0.1309	0.1959	0.2122
CORRELATION COEFFICIENT	0.8402	0.8097	0.3087	0.2522

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	7.7713	1.0904	2.0913	6.3699
MINIMUM OF THE RATIOS:	4.5844	0.6735	0.8837	2.4093
MEAN	5.2559	0.8377	1.2237	3.4924
STANDARD DEVIATION	0.4954	0.0779	0.3060	0.9732
NORMALIZED STANDARD DEVIATION	0.0943	0.0930	0.2500	0.2786

FILE NAME : HL06

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 562.159

STANDARD DEVIATION OF LINE OF INTEREST : 172.686

NORMALIZED STANDARD DEVIATION : 0.3072

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	77.493	521.384	204.064	70.724
STANDARD DEVIATION	20.296	132.208	44.842	17.633
NORMALIZED STANDARD DEVIATION	0.2619	0.2536	0.2197	0.2493
CORRELATION COEFFICIENT	0.9600	0.9590	-0.0593	-0.0961

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	8.4010	1.5715	4.8371	14.0603
MINIMUM OF THE RATIOS:	3.8130	0.6327	0.7050	1.7760
MEAN	7.1707	1.0662	2.8790	8.4282
STANDARD DEVIATION	0.9231	0.1390	1.0027	3.0441
NORMALIZED STANDARD DEVIATION	0.1287	0.1304	0.3483	0.3612

FILE NAME : HL07

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 378.568
 STANDARD DEVIATION OF LINE OF INTEREST : 97.903
 NORMALIZED STANDARD DEVIATION : 0.2586

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	60.191	293.899	375.770	130.675
STANDARD DEVIATION	10.189	80.481	63.330	21.184
NORMALIZED STANDARD DEVIATION	0.1693	0.2738	0.1685	0.1621
CORRELATION COEFFICIENT	0.7624	0.8143	-0.0717	-0.0094

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	9.2280	2.2079	2.6796	7.2162
MINIMUM OF THE RATIOS:	4.4949	0.8207	0.5942	1.7605
MEAN	6.2747	1.3080	1.0466	2.9948
STANDARD DEVIATION	1.0928	0.2250	0.4018	1.0893
NORMALIZED STANDARD DEVIATION	0.1742	0.1720	0.3839	0.3637

RATIO LINE DIODE NUM 3WENT BELOW BACKGROUND ON SCAN 27
 FILE NAME : HL08

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 389.419
 STANDARD DEVIATION OF LINE OF INTEREST : 165.271
 NORMALIZED STANDARD DEVIATION : 0.2804

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	85.226	370.372	505.029	208.875
STANDARD DEVIATION	17.665	130.121	126.054	40.278
NORMALIZED STANDARD DEVIATION	0.2073	0.3513	0.2496	0.1928
CORRELATION COEFFICIENT	0.8429	0.9021	0.0451	-0.2163

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	14.6135	6.3861	1.7695	4.5960
MINIMUM OF THE RATIOS:	1.7975	1.1830	-0.5094	0.3732
MEAN	6.9953	1.8144	1.1641	2.9188
STANDARD DEVIATION	1.5981	0.9062	0.4413	0.9442
NORMALIZED STANDARD DEVIATION	0.2284	0.4994	0.3791	0.3235

FILE NAME : HL09

***** UNRATIED STATISTICS *****

MEAN OF LINE OF INTEREST : 734.707

STANDARD DEVIATION OF LINE OF INTEREST : 141.402

NORMALIZED STANDARD DEVIATION : 0.2200

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	99.680	415.113	626.464	252.980
STANDARD DEVIATION	13.283	102.935	74.812	26.823
NORMALIZED STANDARD DEVIATION	0.1333	0.2480	0.1194	0.1060
CORRELATION COEFFICIENT	0.8433	0.8229	-0.3303	-0.3231

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	9.9105	3.7135	1.7824	4.2995
MINIMUM OF THE RATIOS:	3.9161	0.9939	0.4546	1.2136
MEAN	7.3142	1.8307	1.1956	2.9515
STANDARD DEVIATION	1.0307	0.4411	0.3100	0.7534
NORMALIZED STANDARD DEVIATION	0.1409	0.2410	0.2593	0.2553

FILE NAME : HL10

***** UNRATIED STATISTICS *****

MEAN OF LINE OF INTEREST : 666.657

STANDARD DEVIATION OF LINE OF INTEREST : 170.250

NORMALIZED STANDARD DEVIATION : 0.2554

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	83.481	348.321	547.437	221.905
STANDARD DEVIATION	11.926	98.044	75.116	28.533
NORMALIZED STANDARD DEVIATION	0.1429	0.2815	0.1372	0.1286
CORRELATION COEFFICIENT	0.8691	0.8557	-0.4570	-0.3777

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	10.2191	3.3258	2.2349	5.0915
MINIMUM OF THE RATIOS:	3.7415	1.1934	0.3221	0.8620
MEAN	7.8886	1.9603	1.2578	3.0835
STANDARD DEVIATION	1.2708	0.3732	0.4061	0.9432
NORMALIZED STANDARD DEVIATION	0.1611	0.1904	0.3228	0.3059

FILE NAME : HL11

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 705.964

STANDARD DEVIATION OF LINE OF INTEREST : 157.127

NORMALIZED STANDARD DEVIATION : 0.2226

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	89.507	343.138	625.925	255.717
STANDARD DEVIATION	9.589	93.939	80.461	33.677
NORMALIZED STANDARD DEVIATION	0.1071	0.2738	0.1295	0.1317
CORRELATION COEFFICIENT	0.7922	0.7904	-0.5251	-0.5517

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	9.8556	3.3642	2.1505	5.1115
MINIMUM OF THE RATIOS:	3.6335	1.4329	0.3648	0.8294
MEAN	7.9272	2.1209	1.1637	2.8513
STANDARD DEVIATION	1.2611	0.4102	0.3617	0.9777
NORMALIZED STANDARD DEVIATION	0.1611	0.1934	0.3108	0.3079

FILE NAME : HL12

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 813.254

STANDARD DEVIATION OF LINE OF INTEREST : 175.520

NORMALIZED STANDARD DEVIATION : 0.2158

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	562	972	77	421
MEAN	96.374	337.255	700.970	281.021
STANDARD DEVIATION	7.945	90.150	88.778	36.426
NORMALIZED STANDARD DEVIATION	0.0824	0.2673	0.1267	0.1296
CORRELATION COEFFICIENT	0.6143	0.8391	-0.6702	-0.6724

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	562	972	77	421
MAXIMUM OF THE RATIOS:	10.5692	4.9314	2.3168	5.7088
MINIMUM OF THE RATIOS:	3.5955	1.3598	0.3465	0.8227
MEAN	8.4060	2.5214	1.1992	2.9888
STANDARD DEVIATION	1.5578	0.6101	0.3568	0.8674
NORMALIZED STANDARD DEVIATION	0.1853	0.2420	0.2975	0.2902

B.1.3. Data Set No. 3

File Name	Hydrogen Concentration (%)
HA00	0.00
HA01	0.25
HA02	0.50
HA03	0.75
HA04	1.00
HA05	1.25
HA06	1.50
HA07	1.75
HA08	2.00
HA09	2.25
HA10	2.50
HA11	2.75
HA12	3.00

Element	Wavelength (Å)	Diode Number
Hydrogen	6563.82	146
Argon	6752.83	506
Argon	6965.43	916

.RUN FIXSPC

ENTER THE FILE NAME: HA

EDICR AC
 ENTER THE DIODE NUMBER OF THE LINE OF INTEREST:146
 NOW MANY DIODES SHOULD BE INTEGRATED ON EITHER SIDE OF THE LINE:7

ENTER THE DIODE NUMBERS OF THE LINES TO BE USED FOR AVERAGING.
 TO STOP DATA ENTRY ENTER A RETURN

RATIO DIODE NUMBER 1:506
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 RATIO DIODE NUMBER 2:916
 NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE :7
 RATIO DIODE NUMBER 3:
 DO YOU WANT TO USE A NON-STANDARD BACKGROUND REGION :Y
 ENTER THE BACKGROUND DIODE NUMBER:569
 ENTER THE NUMBER OF DIODES TO BE INTEGRATED ON EITHER SIDE OF THE LINE:10

FILE NAME : HA00

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 101.552
 STANDARD DEVIATION OF LINE OF INTEREST : 10.786
 NORMALIZED STANDARD DEVIATION : 0.1062
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	506	916
MEAN	69.416	523.042
STANDARD DEVIATION	7.469	46.699
NORMALIZED STANDARD DEVIATION	0.1076	0.0893
CORRELATION COEFFICIENT	0.6612	0.6395

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	506	916
MAXIMUM OF THE RATIOS:	1.7127	0.2308
MINIMUM OF THE RATIOS:	1.1291	0.1611
MEAN	1.4682	0.1945
STANDARD DEVIATION	0.1249	0.0158
NORMALIZED STANDARD DEVIATION	0.0851	0.0813

FILE NAME : HA01

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 110.179
 STANDARD DEVIATION OF LINE OF INTEREST : 8.927
 NORMALIZED STANDARD DEVIATION : 0.0810
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 506 916
 MEAN 58.558 426.276
 STANDARD DEVIATION 4.298 41.387
 NORMALIZED STANDARD DEVIATION 0.0734 0.0983
 CORRELATION COEFFICIENT 0.7308 0.7559

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 506 916
 MAXIMUM OF THE RATIOS: 2.1138 0.3031
 MINIMUM OF THE RATIOS: 1.6930 0.2227
 MEAN 1.8833 0.2594
 STANDARD DEVIATION 0.1090 0.0170
 NORMALIZED STANDARD DEVIATION 0.0379 0.0657

FILE NAME : HA02

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 134.664
 STANDARD DEVIATION OF LINE OF INTEREST : 10.423
 NORMALIZED STANDARD DEVIATION : 0.0774
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 506 916
 MEAN 51.479 362.011
 STANDARD DEVIATION 3.952 24.776
 NORMALIZED STANDARD DEVIATION 0.0768 0.0684
 CORRELATION COEFFICIENT 0.6380 0.5773

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 506 916
 MAXIMUM OF THE RATIOS: 3.0463 0.4314
 MINIMUM OF THE RATIOS: 2.3659 0.3120
 MEAN 2.6217 0.3726
 STANDARD DEVIATION 0.1758 0.0249
 NORMALIZED STANDARD DEVIATION 0.0670 0.0669

FILE NAME : HA03

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 189.030
 STANDARD DEVIATION OF LINE OF INTEREST : 11.149
 NORMALIZED STANDARD DEVIATION : 0.0590
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 306 916
 MEAN 60.108 399.860
 STANDARD DEVIATION 3.250 21.837
 NORMALIZED STANDARD DEVIATION 0.0541 0.0546
 CORRELATION COEFFICIENT 0.5062 0.8124

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 306 916
 MAXIMUM OF THE RATIOS: 3.6960 0.3206
 MINIMUM OF THE RATIOS: 2.8567 0.4372
 MEAN 3.1489 0.4729
 STANDARD DEVIATION 0.1809 0.0165
 NORMALIZED STANDARD DEVIATION 0.0574 0.0349

FILE NAME : HA04

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 410.393
 STANDARD DEVIATION OF LINE OF INTEREST : 26.592
 NORMALIZED STANDARD DEVIATION : 0.0648
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 306 916
 MEAN 98.222 500.148
 STANDARD DEVIATION 6.999 44.324
 NORMALIZED STANDARD DEVIATION 0.0713 0.0886
 CORRELATION COEFFICIENT 0.7533 0.8839

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 306 916
 MAXIMUM OF THE RATIOS: 4.7617 0.9123
 MINIMUM OF THE RATIOS: 3.8536 0.7578
 MEAN 4.1848 0.8223
 STANDARD DEVIATION 0.1996 0.0363
 NORMALIZED STANDARD DEVIATION 0.0477 0.0441

FILE NAME : HA05

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 439.062
 STANDARD DEVIATION OF LINE OF INTEREST : 24.944
 NORMALIZED STANDARD DEVIATION : 0.0568
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 506 916
 MEAN 91.496 432.201
 STANDARD DEVIATION 7.420 43.215
 NORMALIZED STANDARD DEVIATION 0.0811 0.1046
 CORRELATION COEFFICIENT 0.8257 0.9084

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 506 916
 MAXIMUM OF THE RATIOS: 5.3689 1.1959
 MINIMUM OF THE RATIOS: 4.3904 0.9225
 MEAN 4.8112 1.0216
 STANDARD DEVIATION 0.2248 0.0629
 NORMALIZED STANDARD DEVIATION 0.0467 0.0616

FILE NAME : HA06

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 521.294
 STANDARD DEVIATION OF LINE OF INTEREST : 39.096
 NORMALIZED STANDARD DEVIATION : 0.0750
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 506 916
 MEAN 93.049 429.557
 STANDARD DEVIATION 8.293 53.894
 NORMALIZED STANDARD DEVIATION 0.0891 0.1255
 CORRELATION COEFFICIENT 0.8334 0.9115

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 506 916
 MAXIMUM OF THE RATIOS: 6.3563 1.4659
 MINIMUM OF THE RATIOS: 4.9865 1.0675
 MEAN 5.6162 1.2226
 STANDARD DEVIATION 0.2889 0.0838
 NORMALIZED STANDARD DEVIATION 0.0514 0.0686

FILE NAME : HA07

```
***** UNRATIOED STATISTICS *****  
MEAN OF LINE OF INTEREST : 690.943  
STANDARD DEVIATION OF LINE OF INTEREST : 38.140  
NORMALIZED STANDARD DEVIATION : 0.0552  
STATISTICS OF LINES USED FOR RATIOING  
DIODE NUMBER OF RATIO LINE      506          916  
MEAN 108.751                      521.176  
STANDARD DEVIATION 7.424           40.865  
NORMALIZED STANDARD DEVIATION 0.0683    0.0784  
CORRELATION COEFFICIENT 0.5921       0.6690
```

```
***** RATIOED DATA *****  
DIODE NUMBER OF RATIO LINE:      506          916  
MAXIMUM OF THE RATIOS: 7.2322     1.4794  
MINIMUM OF THE RATIOS: 5.7980     1.1612  
MEAN 6.3685                      1.3300  
STANDARD DEVIATION 0.3665         0.0779  
NORMALIZED STANDARD DEVIATION 0.0576    0.0586
```

FILE NAME : HA08

```
***** UNRATIOED STATISTICS *****  
MEAN OF LINE OF INTEREST : 693.981  
STANDARD DEVIATION OF LINE OF INTEREST : 38.002  
NORMALIZED STANDARD DEVIATION : 0.0548  
STATISTICS OF LINES USED FOR RATIOING  
DIODE NUMBER OF RATIO LINE      506          916  
MEAN 104.302                      458.279  
STANDARD DEVIATION 6.183           32.619  
NORMALIZED STANDARD DEVIATION 0.0593    0.0712  
CORRELATION COEFFICIENT 0.8174       0.8769
```

```
***** RATIOED DATA *****  
DIODE NUMBER OF RATIO LINE:      506          916  
MAXIMUM OF THE RATIOS: 7.3571     1.6308  
MINIMUM OF THE RATIOS: 6.2740     1.4004  
MEAN 6.6591                      1.5167  
STANDARD DEVIATION 0.2333         0.0532  
NORMALIZED STANDARD DEVIATION 0.0350    0.0351
```


FILE NAME : HA09

```

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 744.037
STANDARD DEVIATION OF LINE OF INTEREST : 39.515
NORMALIZED STANDARD DEVIATION : 0.0800
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      506          916
                                MEAN 102.531     452.203
                                STANDARD DEVIATION 8.373     40.209
NORMALIZED STANDARD DEVIATION 0.0817     0.0889
CORRELATION COEFFICIENT 0.8651     0.9085

```

```

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      506          916
MAXIMUM OF THE RATIOS: 8.1152     1.7963
MINIMUM OF THE RATIOS: 4.8566     1.5361
                                MEAN 7.2643     1.6480
                                STANDARD DEVIATION 0.3108     0.0641
NORMALIZED STANDARD DEVIATION 0.0428     0.0389

```

FILE NAME : HA10

```

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 789.286
STANDARD DEVIATION OF LINE OF INTEREST : 71.788
NORMALIZED STANDARD DEVIATION : 0.0910
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      506          916
                                MEAN 99.469     432.121
                                STANDARD DEVIATION 9.638     44.560
NORMALIZED STANDARD DEVIATION 0.0969     0.1031
CORRELATION COEFFICIENT 0.9235     0.9094

```

```

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      506          916
MAXIMUM OF THE RATIOS: 8.6417     2.0093
MINIMUM OF THE RATIOS: 7.2959     1.6196
                                MEAN 7.9453     1.8305
                                STANDARD DEVIATION 0.2920     0.0800
NORMALIZED STANDARD DEVIATION 0.0367     0.0437

```

FILE NAME : HA11

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 1454.224
 STANDARD DEVIATION OF LINE OF INTEREST : 271.739
 NORMALIZED STANDARD DEVIATION : 0.1869
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 506 916
 MEAN 121.562 659.471
 STANDARD DEVIATION 13.915 125.715
 NORMALIZED STANDARD DEVIATION 0.1145 0.1906
 CORRELATION COEFFICIENT 0.9071 0.9119

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 506 916
 MAXIMUM OF THE RATIOS: 13.7920 2.8950
 MINIMUM OF THE RATIOS: 8.0720 1.7200
 MEAN 11.9677 2.2178
 STANDARD DEVIATION 1.3067 0.2150
 NORMALIZED STANDARD DEVIATION 0.1101 0.0970

FILE NAME : HA12

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 780.359
 STANDARD DEVIATION OF LINE OF INTEREST : 263.059
 NORMALIZED STANDARD DEVIATION : 0.3371
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 506 916
 MEAN 71.192 421.036
 STANDARD DEVIATION 10.093 141.157
 NORMALIZED STANDARD DEVIATION 0.1418 0.3353
 CORRELATION COEFFICIENT 0.8186 0.8684

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 506 916
 MAXIMUM OF THE RATIOS: 16.5502 2.5669
 MINIMUM OF THE RATIOS: 5.5244 0.9000
 MEAN 10.7575 1.8913
 STANDARD DEVIATION 2.5125 0.3417
 NORMALIZED STANDARD DEVIATION 0.2336 0.1807

B.2. Variation of Travel Speed

B.2.1. 1 Percent Hydrogen

File Name	Travel Speed (cm/min)
SA4	10
SA8	20
SA12	30
SA16	40
SA20	50
SA24	60

Element	Wavelength (\AA)	Diode Number
Hydrogen	6563.82	146
Argon	6752.83	506
Argon	6965.43	916

SA4

```

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 372.307
STANDARD DEVIATION OF LINE OF INTEREST : 23.838
NORMALIZED STANDARD DEVIATION : 0.0640
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      506      916
                                MEAN  75.226  542.641
                                STANDARD DEVIATION  4.732  35.230
NORMALIZED STANDARD DEVIATION  0.0629  0.0649
CORRELATION COEFFICIENT  0.7450  0.7148

```

```

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      506      916
MAXIMUM OF THE RATIOS:  5.5555  0.7721
MINIMUM OF THE RATIOS:  4.5866  0.6294
                                MEAN  4.9541  0.6869
                                STANDARD DEVIATION  0.2265  0.0326
NORMALIZED STANDARD DEVIATION  0.0457  0.0475

```

DO YOU WANT TO CALCULATE THESE STATISTICS FOR A DIFFERENT FILE? Y

ENTER THE FILE NAME: SAB
AB

```

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 305.441
STANDARD DEVIATION OF LINE OF INTEREST : 27.622
NORMALIZED STANDARD DEVIATION : 0.0904
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      506      916
                                MEAN  61.337  464.935
                                STANDARD DEVIATION  5.145  36.557
NORMALIZED STANDARD DEVIATION  0.0839  0.0786
CORRELATION COEFFICIENT  0.8657  0.8456

```

```

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      506      916
MAXIMUM OF THE RATIOS:  5.5020  0.7458
MINIMUM OF THE RATIOS:  4.4477  0.5819
                                MEAN  4.9823  0.6571
                                STANDARD DEVIATION  0.2286  0.0316
NORMALIZED STANDARD DEVIATION  0.0459  0.0480

```

SA12

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 353.500
 STANDARD DEVIATION OF LINE OF INTEREST : 25.782
 NORMALIZED STANDARD DEVIATION : 0.0729
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	506	916
MEAN	68.741	514.323
STANDARD DEVIATION	5.030	40.656
NORMALIZED STANDARD DEVIATION	0.0732	0.0790
CORRELATION COEFFICIENT	0.8416	0.8581

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	506	916
MAXIMUM OF THE RATIOS:	5.6556	0.7498
MINIMUM OF THE RATIOS:	4.4021	0.6366
MEAN	5.1470	0.6882
STANDARD DEVIATION	0.2143	0.0290
NORMALIZED STANDARD DEVIATION	0.0416	0.0421

DO YOU WANT TO CALCULATE THESE STATISTICS FOR A DIFFERENT FILE? Y

ENTER THE FILE NAME: SA16
 SA16

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 239.846
 STANDARD DEVIATION OF LINE OF INTEREST : 23.612
 NORMALIZED STANDARD DEVIATION : 0.0984
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	506	916
MEAN	47.795	357.359
STANDARD DEVIATION	4.469	37.835
NORMALIZED STANDARD DEVIATION	0.0935	0.1059
CORRELATION COEFFICIENT	0.9173	0.8479

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	506	916
MAXIMUM OF THE RATIOS:	5.4632	0.7778
MINIMUM OF THE RATIOS:	4.6140	0.6028
MEAN	5.0199	0.6728
STANDARD DEVIATION	0.2001	0.0388
NORMALIZED STANDARD DEVIATION	0.0399	0.0577

SA20

```

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 208.666
STANDARD DEVIATION OF LINE OF INTEREST : 16.503
NORMALIZED STANDARD DEVIATION : 0.0791
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      506      916
MEAN      43.278      314.325
STANDARD DEVIATION      4.921      29.244
NORMALIZED STANDARD DEVIATION      0.1137      0.0930
CORRELATION COEFFICIENT      0.7996      0.8031

```

```

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      506      916
MAXIMUM OF THE RATIOS:      5.7001      0.7743
MINIMUM OF THE RATIOS:      4.2623      0.5896
MEAN      4.8493      0.6656
STANDARD DEVIATION      0.3460      0.0373
NORMALIZED STANDARD DEVIATION      0.0714      0.0560

```

DO YOU WANT TO CALCULATE THESE STATISTICS FOR A DIFFERENT FILE? Y

ENTER THE FILE NAME: SA24
SA24

S

```

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 354.159
STANDARD DEVIATION OF LINE OF INTEREST : 42.568
NORMALIZED STANDARD DEVIATION : 0.1202
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      506      916
MEAN      75.367      525.757
STANDARD DEVIATION      7.804      65.438
NORMALIZED STANDARD DEVIATION      0.1035      0.1245
CORRELATION COEFFICIENT      0.8729      0.9181

```

```

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      506      916
MAXIMUM OF THE RATIOS:      5.2337      0.7560
MINIMUM OF THE RATIOS:      4.1843      0.6098
MEAN      4.6984      0.6748
STANDARD DEVIATION      0.2820      0.0338
NORMALIZED STANDARD DEVIATION      0.0600      0.0501

```

B.2.2. 0.5 Percent Hydrogen

File Name	Travel Speed (cm/min)
SPN4	10
SPN8	20
SPN12	30
SPN16	40
SPN20	50
SPN24	60

Element	Wavelength (Å)	Diode Number
Hydrogen	6563.82	204
Argon	6752.83	564
Argon	6965.43	974

SPN4

```

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 373.325
STANDARD DEVIATION OF LINE OF INTEREST : 97.991
NORMALIZED STANDARD DEVIATION : 0.2625
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      564      974
                                MEAN 146.525    817.685
                                STANDARD DEVIATION 28.663    219.845
NORMALIZED STANDARD DEVIATION 0.1956    0.2689
CORRELATION COEFFICIENT 0.9772    0.9562

```

```

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      564      974
MAXIMUM OF THE RATIOS: 3.1307    0.6770
MINIMUM OF THE RATIOS: 1.5801    0.3365
                                MEAN 2.3026    0.4626
                                STANDARD DEVIATION 0.2907    0.0510
NORMALIZED STANDARD DEVIATION 0.1122    0.1103

```

DO YOU WANT TO CALCULATE THESE STATISTICS FOR A DIFFERENT FILE? Y

ENTER THE FILE NAME: SPN8

```

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 403.479
STANDARD DEVIATION OF LINE OF INTEREST : 72.335
NORMALIZED STANDARD DEVIATION : 0.1805
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      564      974
                                MEAN 158.147    852.178
                                STANDARD DEVIATION 23.520    141.765
NORMALIZED STANDARD DEVIATION 0.1487    0.1664
CORRELATION COEFFICIENT 0.9671    0.9022

```

```

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      564      974
MAXIMUM OF THE RATIOS: 2.7270    0.6356
MINIMUM OF THE RATIOS: 1.8344    0.3125
                                MEAN 2.3364    0.4747
                                STANDARD DEVIATION 0.1753    0.0466
NORMALIZED STANDARD DEVIATION 0.0691    0.0982

```

DO YOU WANT TO CALCULATE THESE STATISTICS FOR A DIFFERENT FILE? Y

ENTER THE FILE NAME: SPN12

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 439.889
 STANDARD DEVIATION OF LINE OF INTEREST : 74.592
 NORMALIZED STANDARD DEVIATION : 0.1696
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974
	MEAN 149.031	775.424
	STANDARD DEVIATION 11.603	53.851
	NORMALIZED STANDARD DEVIATION 0.0779	0.0694
	CORRELATION COEFFICIENT 0.4370	0.6338

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974
MAXIMUM OF THE RATIOS:	5.6065	0.9475
MINIMUM OF THE RATIOS:	2.6371	0.5041
	MEAN 2.9520	0.5661
	STANDARD DEVIATION 0.4508	0.0724
NORMALIZED STANDARD DEVIATION	0.1527	0.1279

DO YOU WANT TO CALCULATE THESE STATISTICS FOR A DIFFERENT FILE? Y

ENTER THE FILE NAME: SPN16

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 361.544
 STANDARD DEVIATION OF LINE OF INTEREST : 41.047
 NORMALIZED STANDARD DEVIATION : 0.1135
 STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE	564	974
	MEAN 129.272	674.216
	STANDARD DEVIATION 10.993	50.845
	NORMALIZED STANDARD DEVIATION 0.0830	0.0754
	CORRELATION COEFFICIENT 0.8595	0.8265

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE:	564	974
MAXIMUM OF THE RATIOS:	3.1341	0.6213
MINIMUM OF THE RATIOS:	2.3987	0.4285
	MEAN 2.7937	0.5385
	STANDARD DEVIATION 0.1703	0.0366
NORMALIZED STANDARD DEVIATION	0.0610	0.0683

DO YOU WANT TO CALCULATE THESE STATISTICS FOR A DIFFERENT FILE? Y

ENTER THE FILE NAME: SPN20

```
***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 394.235
STANDARD DEVIATION OF LINE OF INTEREST : 59.530
NORMALIZED STANDARD DEVIATION : 0.1508
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      564          974
                                MEAN 147.900    753.609
                                STANDARD DEVIATION 16.597    80.323
NORMALIZED STANDARD DEVIATION 0.1122    0.1066
CORRELATION COEFFICIENT 0.9675    0.9480
```

```
***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      564          974
MAXIMUM OF THE RATIOS: 2.9313    0.5805
MINIMUM OF THE RATIOS: 2.3339    0.4684
                                MEAN 2.6605    0.5221
                                STANDARD DEVIATION 0.1343    0.0306
NORMALIZED STANDARD DEVIATION 0.0505    0.0586
```

DO YOU WANT TO CALCULATE THESE STATISTICS FOR A DIFFERENT FILE?

ENTER THE FILE NAME: SPN24

```
***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 400.757
STANDARD DEVIATION OF LINE OF INTEREST : 54.704
NORMALIZED STANDARD DEVIATION : 0.1365
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      564          974
                                MEAN 147.095    821.879
                                STANDARD DEVIATION 17.913    94.016
NORMALIZED STANDARD DEVIATION 0.1218    0.1144
CORRELATION COEFFICIENT 0.9766    0.9416
```

```
***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      564          974
MAXIMUM OF THE RATIOS: 2.9284    0.5293
MINIMUM OF THE RATIOS: 2.3462    0.3977
                                MEAN 2.7185    0.4865
                                STANDARD DEVIATION 0.0993    0.0237
NORMALIZED STANDARD DEVIATION 0.0365    0.0488
```

DO YOU WANT TO CALCULATE THESE STATISTICS FOR A DIFFERENT FILE?

B.3. Filter Simulation on Data Set No. 1.

B.3.1. 10 Å Filter

.RUN FILTER

ENTER THE FILE NAME: HD

ENTER THE DIODE NUMBER OF THE LINE OF INTEREST:204
WHAT IS THE FWHM (IN ANGSTROMS) OF THE FILTER: 10.ENTER THE DIODE NUMBERS OF THE LINES TO BE USED FOR AVERAGING.
TO STOP DATA ENTRY ENTER A RETURNRATIO DIODE NUMBER 1:974
WHAT IS THE FWHM (IN ANGSTROMS) OF THE FILTER: 10.RATIO DIODE NUMBER 2:
DO YOU WANT TO USE A NON-STANDARD BACKGROUND REGION :Y
ENTER THE BACKGROUND DIODE NUMBER:625
WHAT IS THE FWHM (IN ANGSTROMS) OF THE FILTER: 10.

FILE NAME : HD00

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 247.015
STANDARD DEVIATION OF LINE OF INTEREST : 25.716
NORMALIZED STANDARD DEVIATION : 0.1041

STATISTICS OF LINES USED FOR RATIOING

DIODE NUMBER OF RATIO LINE 974
MEAN 854.721
STANDARD DEVIATION 59.193
NORMALIZED STANDARD DEVIATION 0.0693
CORRELATION COEFFICIENT 0.6020

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 0.3319
MINIMUM OF THE RATIOS: 0.2285
MEAN 0.2891
STANDARD DEVIATION 0.0253
NORMALIZED STANDARD DEVIATION 0.0876

FILE NAME : HD01

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 518.644
 STANDARD DEVIATION OF LINE OF INTEREST : 35.955
 NORMALIZED STANDARD DEVIATION : 0.0693
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 1305.669
 STANDARD DEVIATION 93.513
 NORMALIZED STANDARD DEVIATION 0.0716
 CORRELATION COEFFICIENT 0.6080

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 0.4967
 MINIMUM OF THE RATIOS: 0.3309
 MEAN 0.3981
 STANDARD DEVIATION 0.0261
 NORMALIZED STANDARD DEVIATION 0.0633

FILE NAME : HD02

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 489.576
 STANDARD DEVIATION OF LINE OF INTEREST : 35.656
 NORMALIZED STANDARD DEVIATION : 0.0729
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 980.243
 STANDARD DEVIATION 70.745
 NORMALIZED STANDARD DEVIATION 0.0722
 CORRELATION COEFFICIENT 0.7279

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 0.5622
 MINIMUM OF THE RATIOS: 0.4475
 MEAN 0.5001
 STANDARD DEVIATION 0.0270
 NORMALIZED STANDARD DEVIATION 0.0540

FILE NAME : HD03

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 647.067
 STANDARD DEVIATION OF LINE OF INTEREST : 56.773
 NORMALIZED STANDARD DEVIATION : 0.0877
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 1083.350
 STANDARD DEVIATION 68.303
 NORMALIZED STANDARD DEVIATION 0.0630
 CORRELATION COEFFICIENT 0.7408

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 0.7694
 MINIMUM OF THE RATIOS: 0.5461
 MEAN 0.3972
 STANDARD DEVIATION 0.0361
 NORMALIZED STANDARD DEVIATION 0.0604

FILE NAME : HD04

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 1158.936
 STANDARD DEVIATION OF LINE OF INTEREST : 96.197
 NORMALIZED STANDARD DEVIATION : 0.0830
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 1355.200
 STANDARD DEVIATION 106.655
 NORMALIZED STANDARD DEVIATION 0.0787
 CORRELATION COEFFICIENT 0.4894

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.1973
 MINIMUM OF THE RATIOS: 0.7331
 MEAN 0.8583
 STANDARD DEVIATION 0.0783
 NORMALIZED STANDARD DEVIATION 0.0912

FILE NAME : HD05

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1176.520
 STANDARD DEVIATION OF LINE OF INTEREST : 53.836
 NORMALIZED STANDARD DEVIATION : 0.0458
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN1200.090
 STANDARD DEVIATION 51.906
 NORMALIZED STANDARD DEVIATION 0.0433
 CORRELATION COEFFICIENT 0.4444

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.1656
 MINIMUM OF THE RATIOS: 0.8976
 MEAN 0.9814
 STANDARD DEVIATION 0.0478
 NORMALIZED STANDARD DEVIATION0.0487

FILE NAME : HD06

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1130.920
 STANDARD DEVIATION OF LINE OF INTEREST : 93.709
 NORMALIZED STANDARD DEVIATION : 0.0829
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 907.073
 STANDARD DEVIATION 77.619
 NORMALIZED STANDARD DEVIATION 0.0856
 CORRELATION COEFFICIENT 0.8853

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.3428
 MINIMUM OF THE RATIOS: 1.1405
 MEAN 1.2481
 STANDARD DEVIATION 0.0501
 NORMALIZED STANDARD DEVIATION0.0402

FILE NAME : HD07

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1172.442
 STANDARD DEVIATION OF LINE OF INTEREST : 109.941
 NORMALIZED STANDARD DEVIATION : 0.0938
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 772.402
 STANDARD DEVIATION 85.726
 NORMALIZED STANDARD DEVIATION 0.1110
 CORRELATION COEFFICIENT 0.9438

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.6978
 MINIMUM OF THE RATIOS: 1.4133
 MEAN 1.5218
 STANDARD DEVIATION 0.0604
 NORMALIZED STANDARD DEVIATION 0.0397

FILE NAME : HD08

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1414.567
 STANDARD DEVIATION OF LINE OF INTEREST : 119.585
 NORMALIZED STANDARD DEVIATION : 0.0838
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 757.834
 STANDARD DEVIATION 97.705
 NORMALIZED STANDARD DEVIATION 0.1289
 CORRELATION COEFFICIENT 0.7300

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 2.3743
 MINIMUM OF THE RATIOS: 1.6507
 MEAN 1.8842
 STANDARD DEVIATION 0.1820
 NORMALIZED STANDARD DEVIATION 0.0966

FILE NAME : HD09

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1457.847
 STANDARD DEVIATION OF LINE OF INTEREST : 215.317
 NORMALIZED STANDARD DEVIATION : 0.1477
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 702.099
 STANDARD DEVIATION 116.607
 NORMALIZED STANDARD DEVIATION 0.1661
 CORRELATION COEFFICIENT 0.9220

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 2.3673
 MINIMUM OF THE RATIOS: 1.9809
 MEAN 2.0868
 STANDARD DEVIATION 0.1323
 NORMALIZED STANDARD DEVIATION 0.0634

FILE NAME : HD10

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1790.991
 STANDARD DEVIATION OF LINE OF INTEREST : 253.256
 NORMALIZED STANDARD DEVIATION : 0.1414
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 773.178
 STANDARD DEVIATION 113.173
 NORMALIZED STANDARD DEVIATION 0.1464
 CORRELATION COEFFICIENT 0.9291

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 2.6992
 MINIMUM OF THE RATIOS: 2.0712
 MEAN 2.3227
 STANDARD DEVIATION 0.1309
 NORMALIZED STANDARD DEVIATION 0.0564

FILE NAME : HD11

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1869.459
 STANDARD DEVIATION OF LINE OF INTEREST : 273.589
 NORMALIZED STANDARD DEVIATION : 0.1463
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 724.986
 STANDARD DEVIATION 125.294
 NORMALIZED STANDARD DEVIATION 0.1728
 CORRELATION COEFFICIENT 0.9165

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 3.3671
 MINIMUM OF THE RATIOS: 2.2680
 MEAN 2.5958
 STANDARD DEVIATION 0.1966
 NORMALIZED STANDARD DEVIATION 0.0757

FILE NAME : HD12

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :2067.771
 STANDARD DEVIATION OF LINE OF INTEREST : 281.349
 NORMALIZED STANDARD DEVIATION : 0.1189
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 868.188
 STANDARD DEVIATION 112.319
 NORMALIZED STANDARD DEVIATION 0.1294
 CORRELATION COEFFICIENT 0.9491

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 3.0211
 MINIMUM OF THE RATIOS: 2.4419
 MEAN 2.7338
 STANDARD DEVIATION 0.1150
 NORMALIZED STANDARD DEVIATION 0.0421

B.3.2. 20 Å Filter

FILE NAME : HD00

```

***** UNRATIOED STATISTICS *****
  MEAN OF LINE OF INTEREST : 202.713
  STANDARD DEVIATION OF LINE OF INTEREST : 24.109
  NORMALIZED STANDARD DEVIATION : 0.1189
  STATISTICS OF LINES USED FOR RATIOING
    DIODE NUMBER OF RATIO LINE      974
                                MEAN 468.343
                                STANDARD DEVIATION 32.304
                                NORMALIZED STANDARD DEVIATION 0.0689
                                CORRELATION COEFFICIENT 0.5468

```

```

***** RATIOED DATA *****
  DIODE NUMBER OF RATIO LINE:      974
  MAXIMUM OF THE RATIOS: 0.5476
  MINIMUM OF THE RATIOS: 0.3287
                                MEAN 0.4328
                                STANDARD DEVIATION 0.0453
  NORMALIZED STANDARD DEVIATION 0.1047

```

FILE NAME : HD01

```

***** UNRATIOED STATISTICS *****
  MEAN OF LINE OF INTEREST : 408.484
  STANDARD DEVIATION OF LINE OF INTEREST : 22.158
  NORMALIZED STANDARD DEVIATION : 0.0542
  STATISTICS OF LINES USED FOR RATIOING
    DIODE NUMBER OF RATIO LINE      974
                                MEAN 713.230
                                STANDARD DEVIATION 49.201
                                NORMALIZED STANDARD DEVIATION 0.0690
                                CORRELATION COEFFICIENT 0.3807

```

```

***** RATIOED DATA *****
  DIODE NUMBER OF RATIO LINE:      974
  MAXIMUM OF THE RATIOS: 0.7105
  MINIMUM OF THE RATIOS: 0.4979
                                MEAN 0.5746
                                STANDARD DEVIATION 0.0411
  NORMALIZED STANDARD DEVIATION 0.0716

```

FILE NAME : HD02

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 383.178
 STANDARD DEVIATION OF LINE OF INTEREST : 29.323
 NORMALIZED STANDARD DEVIATION : 0.0765
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 538.008
 STANDARD DEVIATION 38.168
 NORMALIZED STANDARD DEVIATION 0.0709
 CORRELATION COEFFICIENT 0.6336

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 0.8087
 MINIMUM OF THE RATIOS: 0.6299
 MEAN 0.7132
 STANDARD DEVIATION 0.0443
 NORMALIZED STANDARD DEVIATION 0.0620

FILE NAME : HD03

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 491.254
 STANDARD DEVIATION OF LINE OF INTEREST : 42.473
 NORMALIZED STANDARD DEVIATION : 0.0865
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 593.254
 STANDARD DEVIATION 37.240
 NORMALIZED STANDARD DEVIATION 0.0628
 CORRELATION COEFFICIENT 0.7147

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.0704
 MINIMUM OF THE RATIOS: 0.7526
 MEAN 0.8281
 STANDARD DEVIATION 0.0513
 NORMALIZED STANDARD DEVIATION 0.0620

FILE NAME : HD04

```
***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 846.039
STANDARD DEVIATION OF LINE OF INTEREST : 61.873
NORMALIZED STANDARD DEVIATION : 0.0731
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      974
                                MEAN 739.524
                                STANDARD DEVIATION 57.534
NORMALIZED STANDARD DEVIATION 0.0779
CORRELATION COEFFICIENT 0.4457

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      974
MAXIMUM OF THE RATIOS: 1.5996
MINIMUM OF THE RATIOS: 1.0008
                                MEAN 1.1498
                                STANDARD DEVIATION 0.1028
NORMALIZED STANDARD DEVIATION 0.0895
```

FILE NAME : HD05

```
***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 859.170
STANDARD DEVIATION OF LINE OF INTEREST : 40.881
NORMALIZED STANDARD DEVIATION : 0.0476
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      974
                                MEAN 654.922
                                STANDARD DEVIATION 30.327
NORMALIZED STANDARD DEVIATION 0.0463
CORRELATION COEFFICIENT 0.4290

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      974
MAXIMUM OF THE RATIOS: 1.5718
MINIMUM OF THE RATIOS: 1.2087
                                MEAN 1.3136
                                STANDARD DEVIATION 0.0685
NORMALIZED STANDARD DEVIATION 0.0522
```

FILE NAME : HD06

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 849.058
 STANDARD DEVIATION OF LINE OF INTEREST : 67.162
 NORMALIZED STANDARD DEVIATION : 0.0791
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 499.562
 STANDARD DEVIATION 40.807
 NORMALIZED STANDARD DEVIATION 0.0817
 CORRELATION COEFFICIENT 0.8699

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.9314
 MINIMUM OF THE RATIOS: 1.5433
 MEAN 1.7014
 STANDARD DEVIATION 0.0695
 NORMALIZED STANDARD DEVIATION 0.0409

FILE NAME : HD07

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 875.748
 STANDARD DEVIATION OF LINE OF INTEREST : 77.950
 NORMALIZED STANDARD DEVIATION : 0.0890
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 424.625
 STANDARD DEVIATION 45.320
 NORMALIZED STANDARD DEVIATION 0.1072
 CORRELATION COEFFICIENT 0.9372

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 2.3492
 MINIMUM OF THE RATIOS: 1.9177
 MEAN 2.0678
 STANDARD DEVIATION 0.0847
 NORMALIZED STANDARD DEVIATION 0.0409

FILE NAME : HD08

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1043.320
 STANDARD DEVIATION OF LINE OF INTEREST : 87.909
 NORMALIZED STANDARD DEVIATION : 0.0843
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 415.338
 STANDARD DEVIATION 53.645
 NORMALIZED STANDARD DEVIATION 0.1292
 CORRELATION COEFFICIENT 0.7456

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 3.1487
 MINIMUM OF THE RATIOS: 2.2301
 MEAN 2.5351
 STANDARD DEVIATION 0.2386
 NORMALIZED STANDARD DEVIATION 0.0941

FILE NAME : HD09

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1066.821
 STANDARD DEVIATION OF LINE OF INTEREST : 158.442
 NORMALIZED STANDARD DEVIATION : 0.1485
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 382.504
 STANDARD DEVIATION 62.834
 NORMALIZED STANDARD DEVIATION 0.1643
 CORRELATION COEFFICIENT 0.9197

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 3.1837
 MINIMUM OF THE RATIOS: 2.3248
 MEAN 2.8017
 STANDARD DEVIATION 0.1782
 NORMALIZED STANDARD DEVIATION 0.0636

FILE NAME : HD10

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1311.342
 STANDARD DEVIATION OF LINE OF INTEREST : 184.930
 NORMALIZED STANDARD DEVIATION : 0.1410
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 423.156
 STANDARD DEVIATION 60.701
 NORMALIZED STANDARD DEVIATION 0.1434
 CORRELATION COEFFICIENT 0.9211

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 3.6229
 MINIMUM OF THE RATIOS: 2.7454
 MEAN 3.1068
 STANDARD DEVIATION 0.1811
 NORMALIZED STANDARD DEVIATION 0.0583

FILE NAME : HD11

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST :1358.319
 STANDARD DEVIATION OF LINE OF INTEREST : 198.908
 NORMALIZED STANDARD DEVIATION : 0.1464
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 394.348
 STANDARD DEVIATION 66.908
 NORMALIZED STANDARD DEVIATION 0.1697
 CORRELATION COEFFICIENT 0.9057

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 4.5334
 MINIMUM OF THE RATIOS: 3.0230
 MEAN 3.4665
 STANDARD DEVIATION 0.2735
 NORMALIZED STANDARD DEVIATION 0.0789

FILE NAME : HD12

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST :1731.665
STANDARD DEVIATION OF LINE OF INTEREST : 210.023
NORMALIZED STANDARD DEVIATION : 0.1213
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 475.506
STANDARD DEVIATION 60.234
NORMALIZED STANDARD DEVIATION 0.1267
CORRELATION COEFFICIENT 0.9403

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 4.0074
MINIMUM OF THE RATIOS: 3.2272
MEAN 3.6460
STANDARD DEVIATION 0.1580
NORMALIZED STANDARD DEVIATION 0.0433

B.3.3. 50 Å Filter

```
.RUN NTYPE
.RUN FILTER

ENTER THE FILE NAME: HD

ENTER THE DIODE NUMBER OF THE LINE OF INTEREST:204
WHAT IS THE FWHM (IN ANGSTROMS) OF THE FILTER: 50.

ENTER THE DIODE NUMBERS OF THE LINES TO BE USED FOR AVERAGING.
TO STOP DATA ENTRY ENTER A RETURN
RATIO DIODE NUMBER 1:974
WHAT IS THE FWHM (IN ANGSTROMS) OF THE FILTER: 50.
RATIO DIODE NUMBER 2:
DO YOU WANT TO USE A NON-STANDARD BACKGROUND REGION :Y
ENTER THE BACKGROUND DIODE NUMBER:625
WHAT IS THE FWHM (IN ANGSTROMS) OF THE FILTER: 50.
```

FILE NAME : HD00

```
***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 134.690
STANDARD DEVIATION OF LINE OF INTEREST : 19.740
NORMALIZED STANDARD DEVIATION : 0.1467
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 200.120
STANDARD DEVIATION 13.690
NORMALIZED STANDARD DEVIATION 0.0684
CORRELATION COEFFICIENT 0.4817

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 0.9009
MINIMUM OF THE RATIOS: 0.4782
MEAN 0.6730
STANDARD DEVIATION 0.0908
NORMALIZED STANDARD DEVIATION 0.1348
```

FILE NAME : HD01

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 258.575
 STANDARD DEVIATION OF LINE OF INTEREST : 15.049
 NORMALIZED STANDARD DEVIATION : 0.0582
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 297.193
 STANDARD DEVIATION 18.966
 NORMALIZED STANDARD DEVIATION 0.0638
 CORRELATION COEFFICIENT -0.1861

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.0953
 MINIMUM OF THE RATIOS: 0.7180
 MEAN 0.8742
 STANDARD DEVIATION 0.0828
 NORMALIZED STANDARD DEVIATION 0.0947

FILE NAME : HD02

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 240.733
 STANDARD DEVIATION OF LINE OF INTEREST : 21.210
 NORMALIZED STANDARD DEVIATION : 0.0881
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 229.464
 STANDARD DEVIATION 15.374
 NORMALIZED STANDARD DEVIATION 0.0679
 CORRELATION COEFFICIENT 0.5191

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.2030
 MINIMUM OF THE RATIOS: 0.9825
 MEAN 1.0306
 STANDARD DEVIATION 0.0930
 NORMALIZED STANDARD DEVIATION 0.0790

FILE NAME : HD03

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 293.017
 STANDARD DEVIATION OF LINE OF INTEREST : 25.693
 NORMALIZED STANDARD DEVIATION : 0.0877
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 250.477
 STANDARD DEVIATION 15.533
 NORMALIZED STANDARD DEVIATION 0.0620
 CORRELATION COEFFICIENT 0.6456

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.3170
 MINIMUM OF THE RATIOS: 1.0422
 MEAN 1.1703
 STANDARD DEVIATION 0.0803
 NORMALIZED STANDARD DEVIATION 0.0686

FILE NAME : HD04

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 473.207
 STANDARD DEVIATION OF LINE OF INTEREST : 29.290
 NORMALIZED STANDARD DEVIATION : 0.0619
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 306.057
 STANDARD DEVIATION 22.981
 NORMALIZED STANDARD DEVIATION 0.0751
 CORRELATION COEFFICIENT 0.2677

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 2.1700
 MINIMUM OF THE RATIOS: 1.3340
 MEAN 1.5540
 STANDARD DEVIATION 0.1452
 NORMALIZED STANDARD DEVIATION 0.0934

FILE NAME : HD05

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 483.731
STANDARD DEVIATION OF LINE OF INTEREST : 25.207
NORMALIZED STANDARD DEVIATION : 0.0521
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 273.102
STANDARD DEVIATION 13.318
NORMALIZED STANDARD DEVIATION 0.0495
CORRELATION COEFFICIENT 0.2989

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 2.1615
MINIMUM OF THE RATIOS: 1.6158
MEAN 1.7744
STANDARD DEVIATION 0.1110
NORMALIZED STANDARD DEVIATION 0.0626

FILE NAME : HD06

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 500.983
STANDARD DEVIATION OF LINE OF INTEREST : 37.127
NORMALIZED STANDARD DEVIATION : 0.0741
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 210.992
STANDARD DEVIATION 15.958
NORMALIZED STANDARD DEVIATION 0.0732
CORRELATION COEFFICIENT 0.8034

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 2.5958
MINIMUM OF THE RATIOS: 2.1183
MEAN 2.3767
STANDARD DEVIATION 0.1104
NORMALIZED STANDARD DEVIATION 0.0465

FILE NAME : HD07

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 312.388
 STANDARD DEVIATION OF LINE OF INTEREST : 41.666
 NORMALIZED STANDARD DEVIATION : 0.0913
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 177.998
 STANDARD DEVIATION 17.878
 NORMALIZED STANDARD DEVIATION 0.1004
 CORRELATION COEFFICIENT 0.9016

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 3.4340
 MINIMUM OF THE RATIOS: 2.6456
 MEAN 2.8871
 STANDARD DEVIATION 0.1388
 NORMALIZED STANDARD DEVIATION 0.0481

FILE NAME : HD08

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 397.730
 STANDARD DEVIATION OF LINE OF INTEREST : 49.897
 NORMALIZED STANDARD DEVIATION : 0.0835
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 173.761
 STANDARD DEVIATION 22.310
 NORMALIZED STANDARD DEVIATION 0.1295
 CORRELATION COEFFICIENT 0.7364

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 4.2712
 MINIMUM OF THE RATIOS: 3.0165
 MEAN 3.4721
 STANDARD DEVIATION 0.3299
 NORMALIZED STANDARD DEVIATION 0.0950

FILE NAME : HD09

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 602.622
 STANDARD DEVIATION OF LINE OF INTEREST : 88.335
 NORMALIZED STANDARD DEVIATION : 0.1469
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 158.365
 STANDARD DEVIATION 25.024
 NORMALIZED STANDARD DEVIATION 0.1578
 CORRELATION COEFFICIENT 0.9097

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 4.3498
 MINIMUM OF THE RATIOS: 3.3762
 MEAN 3.8142
 STANDARD DEVIATION 0.2453
 NORMALIZED STANDARD DEVIATION 0.0643

FILE NAME : HD10

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 739.252
 STANDARD DEVIATION OF LINE OF INTEREST : 101.293
 NORMALIZED STANDARD DEVIATION : 0.1370
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 176.854
 STANDARD DEVIATION 23.852
 NORMALIZED STANDARD DEVIATION 0.1349
 CORRELATION COEFFICIENT 0.8898

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 4.9684
 MINIMUM OF THE RATIOS: 3.6446
 MEAN 4.1897
 STANDARD DEVIATION 0.2729
 NORMALIZED STANDARD DEVIATION 0.0651

FILE NAME : HD11

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 753.917
STANDARD DEVIATION OF LINE OF INTEREST : 108.098
NORMALIZED STANDARD DEVIATION : 0.1434
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 163.237
STANDARD DEVIATION 26.584
NORMALIZED STANDARD DEVIATION 0.1629
CORRELATION COEFFICIENT 0.8630

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 6.2246
MINIMUM OF THE RATIOS: 3.9261
MEAN 4.6501
STANDARD DEVIATION 0.4220
NORMALIZED STANDARD DEVIATION 0.0907

FILE NAME : HD12

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 968.400
STANDARD DEVIATION OF LINE OF INTEREST : 117.300
NORMALIZED STANDARD DEVIATION : 0.1212
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 198.608
STANDARD DEVIATION 23.596
NORMALIZED STANDARD DEVIATION 0.1188
CORRELATION COEFFICIENT 0.9040

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 5.5148
MINIMUM OF THE RATIOS: 4.1804
MEAN 4.8807
STANDARD DEVIATION 0.2541
NORMALIZED STANDARD DEVIATION 0.0521

B.3.4. 100 Å Filter

```
.RUN FILTER
```

```
ENTER THE FILE NAME: HD
```

```
ENTER THE DIODE NUMBER OF THE LINE OF INTEREST:204  
WHAT IS THE FWHM (IN ANGSTROMS) OF THE FILTER: 100.
```

```
ENTER THE DIODE NUMBERS OF THE LINES TO BE USED FOR AVERAGING.  
TO STOP DATA ENTRY ENTER A RETURN
```

```
RATIO DIODE NUMBER 1:974  
WHAT IS THE FWHM (IN ANGSTROMS) OF THE FILTER: 100.  
RATIO DIODE NUMBER 2:
```

```
DO YOU WANT TO USE A NON-STANDARD BACKGROUND REGION :Y  
ENTER THE BACKGROUND DIODE NUMBER:625  
WHAT IS THE FWHM (IN ANGSTROMS) OF THE FILTER: 100.
```

```
FILE NAME : HD00
```

```
***** UNRATIOED STATISTICS *****  
MEAN OF LINE OF INTEREST : 91.391  
STANDARD DEVIATION OF LINE OF INTEREST : 15.386  
NORMALIZED STANDARD DEVIATION : 0.1684  
STATISTICS OF LINES USED FOR RATIOING  
DIODE NUMBER OF RATIO LINE 974  
MEAN 93.367  
STANDARD DEVIATION 7.415  
NORMALIZED STANDARD DEVIATION 0.0794  
CORRELATION COEFFICIENT 0.1998
```

```
***** RATIOED DATA *****  
DIODE NUMBER OF RATIO LINE: 974  
MAXIMUM OF THE RATIOS: 1.4378  
MINIMUM OF THE RATIOS: 0.6344  
MEAN 0.9828  
STANDARD DEVIATION 0.1777  
NORMALIZED STANDARD DEVIATION 0.1809
```


FILE NAME : HD01

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 173.804
 STANDARD DEVIATION OF LINE OF INTEREST : 12.642
 NORMALIZED STANDARD DEVIATION : 0.0727
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 134.923
 STANDARD DEVIATION 11.747
 NORMALIZED STANDARD DEVIATION 0.0871
 CORRELATION COEFFICIENT -0.4872

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.6784
 MINIMUM OF THE RATIOS: 0.9843
 MEAN 1.3015
 STANDARD DEVIATION 0.1770
 NORMALIZED STANDARD DEVIATION 0.1360

FILE NAME : HD02

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 157.524
 STANDARD DEVIATION OF LINE OF INTEREST : 15.973
 NORMALIZED STANDARD DEVIATION : 0.1014
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 105.179
 STANDARD DEVIATION 8.045
 NORMALIZED STANDARD DEVIATION 0.0765
 CORRELATION COEFFICIENT 0.1973

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 1.8469
 MINIMUM OF THE RATIOS: 1.1473
 MEAN 1.3039
 STANDARD DEVIATION 0.1724
 NORMALIZED STANDARD DEVIATION 0.1146

FILE NAME : HD03

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 183.908
 STANDARD DEVIATION OF LINE OF INTEREST : 17.163
 NORMALIZED STANDARD DEVIATION : 0.0933
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 115.417
 STANDARD DEVIATION 8.417
 NORMALIZED STANDARD DEVIATION 0.0729
 CORRELATION COEFFICIENT 0.5233

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 2.0368
 MINIMUM OF THE RATIOS: 1.3546
 MEAN 1.3963
 STANDARD DEVIATION 0.1344
 NORMALIZED STANDARD DEVIATION 0.0842

FILE NAME : HD04

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 284.180
 STANDARD DEVIATION OF LINE OF INTEREST : 16.753
 NORMALIZED STANDARD DEVIATION : 0.0590
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 140.619
 STANDARD DEVIATION 13.545
 NORMALIZED STANDARD DEVIATION 0.0963
 CORRELATION COEFFICIENT 0.0215

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 3.0480
 MINIMUM OF THE RATIOS: 1.6368
 MEAN 2.0426
 STANDARD DEVIATION 0.2612
 NORMALIZED STANDARD DEVIATION 0.1279

FILE NAME : HD05

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 289.804
 STANDARD DEVIATION OF LINE OF INTEREST : 17.098
 NORMALIZED STANDARD DEVIATION : 0.0590
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 125.463
 STANDARD DEVIATION 7.024
 NORMALIZED STANDARD DEVIATION 0.0560
 CORRELATION COEFFICIENT 0.0440

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 2.9297
 MINIMUM OF THE RATIOS: 2.0472
 MEAN 2.3172
 STANDARD DEVIATION 0.1917
 NORMALIZED STANDARD DEVIATION 0.0827

FILE NAME : HD06

***** UNRATIOED STATISTICS *****
 MEAN OF LINE OF INTEREST : 313.668
 STANDARD DEVIATION OF LINE OF INTEREST : 22.592
 NORMALIZED STANDARD DEVIATION : 0.0720
 STATISTICS OF LINES USED FOR RATIOING
 DIODE NUMBER OF RATIO LINE 974
 MEAN 87.584
 STANDARD DEVIATION 8.217
 NORMALIZED STANDARD DEVIATION 0.0938
 CORRELATION COEFFICIENT 0.0418

***** RATIOED DATA *****
 DIODE NUMBER OF RATIO LINE: 974
 MAXIMUM OF THE RATIOS: 4.0098
 MINIMUM OF THE RATIOS: 2.9655
 MEAN 3.3966
 STANDARD DEVIATION 0.2564
 NORMALIZED STANDARD DEVIATION 0.0713

FILE NAME : HD07

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 319.068
STANDARD DEVIATION OF LINE OF INTEREST : 24.408
NORMALIZED STANDARD DEVIATION : 0.0765
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 73.413
STANDARD DEVIATION 8.518
NORMALIZED STANDARD DEVIATION 0.1160
CORRELATION COEFFICIENT 0.7921

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 5.6479
MINIMUM OF THE RATIOS: 3.8369
MEAN 4.3762
STANDARD DEVIATION 0.3470
NORMALIZED STANDARD DEVIATION 0.0793

FILE NAME : HD08

***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 364.893
STANDARD DEVIATION OF LINE OF INTEREST : 29.955
NORMALIZED STANDARD DEVIATION : 0.0821
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 73.109
STANDARD DEVIATION 10.084
NORMALIZED STANDARD DEVIATION 0.1379
CORRELATION COEFFICIENT 0.7113

***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 6.5472
MINIMUM OF THE RATIOS: 4.2467
MEAN 5.0492
STANDARD DEVIATION 0.5409
NORMALIZED STANDARD DEVIATION 0.1071

FILE NAME : HD09

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 363.190
STANDARD DEVIATION OF LINE OF INTEREST : 52.630
NORMALIZED STANDARD DEVIATION : 0.1449
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 68.322
STANDARD DEVIATION 10.338
NORMALIZED STANDARD DEVIATION 0.1542
CORRELATION COEFFICIENT 0.9734

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 6.6327
MINIMUM OF THE RATIOS: 4.5480
MEAN 5.3386
STANDARD DEVIATION 0.4107
NORMALIZED STANDARD DEVIATION 0.0769

FILE NAME : HD10

***** UNRATIOED STATISTICS *****

MEAN OF LINE OF INTEREST : 443.330
STANDARD DEVIATION OF LINE OF INTEREST : 58.833
NORMALIZED STANDARD DEVIATION : 0.1327
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE 974
MEAN 75.679
STANDARD DEVIATION 10.390
NORMALIZED STANDARD DEVIATION 0.1399
CORRELATION COEFFICIENT 0.8324

***** RATIOED DATA *****

DIODE NUMBER OF RATIO LINE: 974
MAXIMUM OF THE RATIOS: 7.1392
MINIMUM OF THE RATIOS: 4.7891
MEAN 5.3849
STANDARD DEVIATION 0.4700
NORMALIZED STANDARD DEVIATION 0.0799

FILE NAME : HD11

```
***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 445.517
STANDARD DEVIATION OF LINE OF INTEREST : 62.023
NORMALIZED STANDARD DEVIATION : 0.1392
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      974
                                MEAN  71.197
                                STANDARD DEVIATION  12.868
                                NORMALIZED STANDARD DEVIATION  0.1807
                                CORRELATION COEFFICIENT  0.7771
```

```
***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      974
MAXIMUM OF THE RATIOS:  8.9480
MINIMUM OF THE RATIOS:  4.7743
                                MEAN  6.3479
                                STANDARD DEVIATION  0.8098
NORMALIZED STANDARD DEVIATION  0.1276
```

FILE NAME : HD12

```
***** UNRATIOED STATISTICS *****
MEAN OF LINE OF INTEREST : 572.520
STANDARD DEVIATION OF LINE OF INTEREST : 60.200
NORMALIZED STANDARD DEVIATION : 0.1192
STATISTICS OF LINES USED FOR RATIOING
DIODE NUMBER OF RATIO LINE      974
                                MEAN  84.074
                                STANDARD DEVIATION  11.206
                                NORMALIZED STANDARD DEVIATION  0.1333
                                CORRELATION COEFFICIENT  0.7941
```

```
***** RATIOED DATA *****
DIODE NUMBER OF RATIO LINE:      974
MAXIMUM OF THE RATIOS:  9.4979
MINIMUM OF THE RATIOS:  5.2752
                                MEAN  6.8434
                                STANDARD DEVIATION  0.5700
NORMALIZED STANDARD DEVIATION  0.0833
```

REFERENCES

- [1] W. F. Savage, E. F. Nippes and E. I. Musa, "Hydrogen-assisted cracking in HY-130 weldments," Welding J., vol. 61, no. 8, pp. 233s-242s, August 1982.
- [2] A. R. Troiano, "The role of interstitials in the mechanical behavior of metals," Trans. ASM, vol. 52, pp. 54-80, 1960.
- [3] B. Chew, "Prediction of weld metal hydrogen levels obtained under test conditions," Welding Journal, vol. 52, no. 9, September 1973.
- [4] M. E. Norris and C. S. Gardner, "Microprocessor controlled weld arc spectrum analyzer," Radio Res. Lab. Rep. 512 (University of Illinois, Urbana, IL, 1981).
- [5] J. M. Somerville, The Electric Arc. New York: John Wiley and Sons, Inc., 1959, pp. 24-28.
- [6] J. T. Verdeyen, Laser Electronics. New Jersey: Prentice-Hall, 1981, pp. 141-150.
- [7] I. N. Levine, Physical Chemistry. New York: McGraw-Hill, 1978, pp. 420.
- [8] H. R. Griem, Spectral Line Broadening by Plasmas. New York: Academic Press, 1974, pp. 4-31.
- [9] G. Bekefi, C. Deutsch and B. Yaakobi, "Spectroscopic diagnostics of laser plasmas," in Principles of Laser Plasmas, G. Bekefi, Ed. New York: John Wiley and Sons, 1976, pp. 549-559.
- [10] T. Holstein, "Imprisonment of resonance radiation in gases," Physical Review, vol. 72, no. 12, pp. 1212-1233, 1947.
- [11] "HR-320 Instruction Manual," Metuchen, NJ: Instruments S. A. Inc., 1979, p. 4.
- [12] "Optics Guide 2," Irvine, CA: Melles Griot Inc., 1982, pp. 242-245.